

---

---

## *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date:* 2/9/2010

---

---

*Out Time:* *In Time:*  
*(Begin:)* *(End:)*

7:17	8:19	Kress Interchange - Adding SF6 gas to cap breaker 9708.
8:15	14:47	Denver City Interchange - Op Checking Breaker W900.
8:59		Bailey Co Interchange to Curry Co Interchange Z50 is under hot line conditions from the Bailey Co end to pull new conductor over the circuit.
10:00		Deaf Smith Co Interchange BKR 5H50 CA and mechanism.
10:34		Yoakum Co Interchange - CA breaker 6K50. The load is on the transfer breaker during this TWR.
	11:24	Jones Sta TWR on breaker JK15 has been released and terminated.
11:45	17:21	PCA Interchange - Op checking Breaker 4975
12:10	17:47	Eddy Co Interchange - CA Transformer Breaker 4970
12:59		Jones Sta - CA breaker JK25. Load has been moved to the transfer breaker.
13:05	13:48	Lamton Interchange - TWR to CA breaker 7H90.
13:32		Potter Co Interchange - TWR for CA and Mechanism overhaul on BLR 2K35.
14:40	15:30	Lea National to Maljamar V84 is under hot line conditions for line maintenance.
15:55	18:04	Roosevelt Co Interchange low operating pressure. BKR 4960 compressor motor burned up. Replaced compressor motor and the alarm is clear.
15:56	18:46	Potash Jct. Interchange to Livingston Ridge Z22 is under hot line conditions to repair broken isulators.
16:07	16:40	Hobb Generating Sta TWR to add SF6 gas to BKR 4H220.
17:19		Carriers tested good.