
Xcel Energy South Control Center Daily Operations Report

Date: 2/16/2010

Out Time: In Time:
(Begin:) (End:)

9:34	13:04	Norton - CA Bkr 3H285
10:31	14:50	Chaves Co Interchange 115 KV breaker 4H95 out for C/A and maintenance. Temporary release and termination.
10:42	15:31	Denver City Interchange 115 KV breaker W915 out for C/A and testing.
11:09	12:40	Grapevine Interchange - Perform CA on Breaker 5995
11:44		Harrington Sta to Potter Co Interchange K58 is out of service to perform line maintenance.
11:51	16:12	Hale Co Interchange to Plainview/Tuco Intg Z18 doing the work to return circuit to normal after storm damage repair.
11:56		Nichols Sta to Northwest Interchange V28 is isolated from Cherry St Sub to Nichols to perform line maintenance.
12:13	12:59	Norton - Repairing switch 3H286
13:02	17:27	Texas Co Interchange - Perform CA on breaker 0804
13:22		Osage Sw Sta - Perform CA on breaker 5H85
14:31	14:58	Graham Interchange 69 KV breaker 6F75 by-passed to add SF-6 gas.
17:02	17:17	Carriers tested O.K.
	17:37	Seminole Intg 115 KV breaker 6H155 work completed for this TWR.