

---

---

# *Xcel Energy South Control Center Daily Operations Report*

---

---

*Date: 2/25/2010*

---

---

*Out Time: In Time:*  
*(Begin:) (End:)*

3:38 Curtailment -SPP issued TLR 3B on Temp 1 flowgate, loss of K11 (Bushland/Deafsmith) overloads ( V5 Osage/Canyon).  
SPP released TLR to level 0.

6:42 7:27 Curtailment SPP issued TLR 3B on flowgate Temp #5 - loss of K46(Plt X/Sundown)overloads K42(Tolk/Tuco) called for TLR 3B.  
SPP released TLR on Temp #5 to level 0

8:02 16:14 Lamton Interchange  
D/L clearance established to replace structures.  
  
Released and Terminated

8:49 13:45 Maddox  
H/L clearance established for line maint.

8:57 16:35 Midland - Replace oil in the LTC  
  
Released and Terminated

9:00 10:13 Lamb Co Interchange - Performing a CA on Transformer breaker 3990

9:01 16:09 Lamb Co Interchange to Tuco Interchange Y79  
H/L clearance established for SPEC.  
  
Released and Terminated

9:14 17:12 Gray Co Interchange to Adobe Creek Z74 is under hot line conditions to dig foundations.

9:57 Roosevelt Co Interchange - Performing a CA on breaker 8917

10:05 Lea Co Interchange  
Work completed TWR terminated

10:30 16:00 Osage Sw Sta - Performing a CA on breaker 5H25

10:35 Maddox  
Work completed. TWR terminated

---

---

## ***Xcel Energy South Control Center Daily Operations Report***

***Date:*** 2/25/2010

---

---

***Out Time:*** ***In Time:***  
***(Begin:)***      ***(End:)***

<b>10:43</b>	<b>15:54</b>	<b>Mustang Interchange TWR established to troubleshoot wiring</b>
<b>10:56</b>	<b>14:42</b>	<b>Amoco Wasson TWR established to CA and Test bkr 7K60</b>
	<b>14:34</b>	<b>AEP-WTU reported work has been completed with 69kv line Clarendon. Hedley to Lighthouse Rec. Hold on Kirby to Jerico to remain normal was released.</b>
<b>17:30</b>		<b>Carriers tested good.</b>
	<b>18:48</b>	<b>Lea National to Maljamar V84 - TWR to install jumpers to by- pass switch 4H53 at Lea National and removed jumpers to the shoo-fly.  Released and terminated.</b>
<b>19:04</b>	<b>23:00</b>	<b>Indiana - LOP alarm, was distribution bkr.</b>