
Xcel Energy South Control Center Daily Operations Report

Date: 2/28/2010

Out Time: In Time:
(Begin:) (End:)

10:06 10:06 Happy 69KV BKR 3765 operated 1 time and closed back.
This serves the Swisher West Ckt out of Happy Intg.

Swisher REC found a problem at their "Center Plains Sub".

10:08 10:08 Happy 69KV BKR 3765 operated 1 time and closed back.
This serves the Swisher West Ckt out of Happy Intg.

Swisher REC found a problem at their "Center Plains Sub".

10:12 10:12 Happy 69KV BKR 3765 operated 1 time and closed back.
This serves the Swisher West Ckt out of Happy Intg.

Swisher REC found a problem at their "Center Plains Sub".

10:13 10:13 Happy 69KV BKR 3765 operated 1 time and closed back.
This serves the Swisher West Ckt out of Happy Intg.

Swisher REC found a problem at their "Center Plains Sub".

10:20 10:20 Happy 69KV BKR 3765 O/C/O/C
This serves the Swisher West Ckt out of Happy Intg.

Swisher REC found a problem at their "Center Plains Sub".

10:20 10:20 Happy 69KV BKR 3765 operated 1 times and closed back.
This serves the Swisher West Ckt out of Happy Intg.

Swisher REC found a problem at their "Center Plains Sub".

19:07 SPP issued TLR 3B on permanent flowgate 5368 (Loss of
Swisher/Tuco K1 will overload Kress/Hale V72)

SPP raised TLR on Flowgate 5368 upgraded to 5A for schedule
feasibility.

SWPP released TLR 5368

Xcel Energy South Control Center Daily Operations Report

Date: 2/28/2010

Out Time: In Time:
(Begin:) (End:)

21:27 **Hereford Interchange - Scada indicated North LOP, notified DDC**

Sube reported low oil on compressor on 69kv capacitor breaker 2885.
 Tagged breaker to leave capacitor out of service. Will repair compressor during regular working hours.

22:08 **SWPP issued TLR 3B on permanent flowgate 5368 (Loss of Swisher/Tuco K1 will overload Kress/Hale V72)**

Released TLR to level zero 3/1/2010 @ 06:28.