
Xcel Energy South Control Center Daily Operations Report

Date: 3/7/2010

Out Time: *In Time:*
(Begin:) *(End:)*

SPP issued TLR 3B for flow gate Temp #1 (Loss fo K11
Bushland to Deaf Smith overloads V5 Osage to Canyon)

8:27 SPP released TLR 3B for flow gate Temp #1- (Loss of
Bushland-Deaf Smith will overload Osage to Canyon)

8:58 Helicopter will patrol ckts V83 and V84

9:35 Completed weekly Mission Mode test.

19:35 19:50 Perform carrier test.