
Xcel Energy South Control Center Daily Operations Report

Date: 3/14/2010

Out Time: In Time:
(Begin:) (End:)

13:37 Curtailment - SPP released TLR 3 on flowgate #5354 to zero (loss of K63 Ama S./ Swisher - overloads T66 - Randall /Happy)

15:18 **15:52** Whitten 115KV BKR 3H180 out to add SF6 gas.