

Feasibility Study Report for PSCo OASIS Request # GI-2004-1

Generation Interconnection Request for a 150 MW Wind Generation Facility Near Ft. Morgan, Colorado

Xcel Energy Transmission Planning
June 18, 2004

Executive Summary

PSCo Transmission received a generation request to determine the feasibility of interconnecting 150 MW of new Customer wind turbine generation into the PSCo transmission system at the Pawnee Station 230 kV bus. The Customer proposed commercial operation date is December 31, 2005 with a back feed date of June 1, 2005.

This study shows that after execution of an Interconnection Agreement (IA), the Customer can interconnect within 9 months and deliver the full 150 MW in 24 months.

The Customer requested both an ER (Energy Resource) and an NR (Network Resource) Interconnection Service into the Pawnee Station 230 kV bus via the Customer's 18-20 mile line. The ER portion of this study determined that the transmission system could accept approximately 62 MW of the proposed Customer generation before additional transmission infrastructure would be required. This determination is dependent upon the loading of the TOT 3 import path as well as assumed infrastructure additions required to accommodate the delivery of proposed generation from pending higher queued interconnection requests. In this case TOT 3 was loaded to a high level of 1470 MW and the TOT 3 limit was 1543 MW based on operating studies for Summer 2004. If the flows are lower on the TOT 3 path, the existing transmission system could accept higher levels of generation from the proposed wind farm. If the assumed infrastructure additions as part of higher queued interconnection requests are not constructed, the amount of delivery for the ER request would be zero (0). The current PSCo generation interconnection queue can be found in Appendix E.

The estimated cost of designing and constructing the new PSCo interconnection facilities required to interconnect the new Customer wind turbine generation into the Pawnee Station 230 kV bus is \$625,000. The estimated time required to engineer, permit, and construct the network upgrades associated with interconnection is at least 9 months from the time an (IA) is signed. As per the Customer's request, this study assumed that the Customer would engineer, permit, construct, pay, and fund their 230 kV transmission line that will interconnect at the Pawnee Station 230 kV bus.

As a NR request, PSCo evaluated the network to determine the upgrades required to deliver the full 150 MW of the wind facility to PSCo native load Customers. Powerflow studies show that the 150 MW injection into the PSCo system in 2006 will create overloads on the PSCo system and increase overloads on nearby neighboring systems, thus network upgrades are required to relieve these problems. The initial upgrades will consist of an uprate of the PSCo Ft. Lupton Station-Henry Lake Substation –Riverdale Substation-Cherokee Station 230kV transmission line from its current rating of 435 MVA to at least 460 MVA. Preliminary engineering has determined that this will require changing jumpers on termination equipment at Riverdale Substation and Cherokee Station at an estimated cost of \$153,000. Due to the position of this request in the PSCo generation interconnection queue, other upgrades will be required in 2008 as a result of this project's influence on request GI-2003-2 in 2008. This will require upgrading PSCo's 115 kV line from Ft. Lupton Station to Cherokee Station to 230 kV operation with an 800 MVA rating. The estimated cost for this upgrade is \$23,595,000.

In summary, total requirements for a NR interconnection request includes:

- \$625,000 for Pawnee Station interconnection facilities required in 2006.
- \$153,000 for the Ft.Lupton Station –Henry Lake Substation-Riverdale Substation to Cherokee Station 230kV line uprate required in 2006.
- \$23,595,000 to upgrade the Ft. Lupton Station – Cherokee Station 115kV line to 230kV required in 2008.

Total NR cost is estimated at \$24,373,000. The time required to engineer, permit, and construct all the required PSCo facilities, including the 115 kV to 230 kV conversion, is at least 24 months from the time an Interconnection Agreement (IA) is signed. The cost responsibilities associated with these PSCo facilities, if constructed, would be handled as per applicable FERC policies.

Other impacts on TOT 3 and the neighboring utilities were monitored, but not addressed in the scope of this study. Should the Customer continue this request

and move on to the System Impact Study, all impacts on the PSCo and neighboring utilities will be identified and these studies would include participation from those Affected Systems Operators/Planners.

It should be noted that if infrastructure associated GI-2003-1 is not constructed, then additional facilities and time will be required to support both an ER and NR request. Specifically, those facilities estimated in GI-2003-1 Feasibility Study associated with an NR request consist of the following:

- 1) Upgrade the PSCo 230 kV line from Pawnee Station to Quincy Substation and on to Smoky Hill Substation.
- 2) Upgrade the PSCo 230 kV line from Pawnee Station to Ft. Lupton Station to a 230 kV double circuit, 800 MVA per circuit rated transmission line.

PSCo estimated that it would take at least 27 months to construct the above facilities from the execution of an IA. The completed GI-2003-1 Feasibility study report is available via the Rocky Mountain Area Oasis (www.rmao.com).

Introduction

PSCo Transmission received this large generator interconnection request (GI-2004-1) to interconnect one hundred (100) 1.5 MW, GE doubly fed induction generator (DFIG) wind turbines, for a total of 150 MW generation, with a commercial operation date of December 31, 2005 and a back feed date of June 1, 2005. The proposed wind farm would be located near Ft. Morgan, Colorado and would interconnect into the PSCo transmission system via an 18-20 mile radial 230 kV line terminating at the PSCo Pawnee Station. The Customer has requested that this Project be evaluated as a Network Resource (NR) and an Energy Resource (ER) with the energy going to PSCo Customers.

Study Scope and Analysis

The Interconnection Feasibility Study preliminarily evaluated the transmission requirements associated with the proposed interconnection to the PSCo Transmission System. As per section 6.2 of the FERC LGIP, the Study considered the Base Case as well as all Generating Facilities (and with respect to (iii), any identified Network Upgrades) that, on the date the Interconnection Feasibility Study is commenced:

- (i) are directly interconnected to the Transmission System;

- (ii) are interconnected to Affected Systems and may have an impact on the Interconnection Request;
- (iii) that have a pending higher queued Interconnection Request to interconnect to the Transmission System; and
- (iv) have no Queue Position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC.

The Study consisted of power flow and short circuit analyses. The power flow analysis provided a preliminary identification of any thermal or voltage limit violations resulting for the interconnection; and for a NR request, a preliminary identification of network upgrades required to deliver the proposed generation to PSCo loads. The short circuit analysis provided a preliminary identification of any circuit breaker short circuit capability limits exceeded as a result of the Interconnection and for a NR request, the delivery of the proposed generation to PSCo loads.

PSCo adheres to NERC / WECC Reliability Criteria, as well as internal Company criteria for planning studies. During system intact conditions, criteria are to maintain transmission system bus voltages between 0.95 and 1.05 per-unit of system nominal / normal conditions, and steady state power flows within 1.0 per-unit of all elements thermal (continuous current or MVA) ratings. Operationally, PSCo tries to maintain a transmission system voltage profile ranging from 1.02 per-unit or higher at generation buses, to 1.0 per-unit or higher at transmission load buses. Following a single contingency element outage, transmission system steady state bus voltages must remain within 0.90 per-unit to 1.10 per-unit, and power flows within 1.0 per-unit of the elements continuous thermal ratings.

Power Flow Study Models:

The power flow study used a 2006 heavy summer power flow model with high TOT 3 load flow that was created from the Western Electricity Coordinating Council (WECC) 2004 Heavy Summer Case Operating case. The Tot 3 limit was assumed to be 1543 MW, based on 2004 summer studies. This study did not include a comprehensive analysis of how the TOT3 limit might be affected by this project. A full TOT 3 analysis would be part of a later Interconnection System Impact Study during which the Affected System Operators would need to take part in the system analysis. Appendix A details the transmission lines that comprise the TOT 3 interface.

To evaluate the impact of this request on those ahead in the PSCo Interconnection Queue (See Appendix E), another set of load flow cases with heavy summer 2010 loads and resources were used that were based on the

WECC 2008 Heavy Summer case. The generators in the interconnection queue that affect this request are as follows:

1. GI-2003-1: 300 MW Wind Farm connected to Pawnee Station and its associated infrastructure with a proposed ISD of 12/05. The infrastructure identified in GI-2003-1 consists of the following:
 - a. Upgrade the 94 mile PSCo 230 KV line from Pawnee Station to Quincy and Smoky Hill Substations from 500 MVA to 800 MVA.
 - b. Upgrade the PSCo 64 mile 230 kV line from Pawnee Station to Ft. Lupton Station to a 230 kV double circuit, 800 MVA per circuit rated transmission line.
2. GI-2003-2: 500 MW Coal fired generator connecting to the Pawnee to Daniels Park 230 kV line near Deer Trail, Colorado and its associated infrastructure with a proposed ISD of 10/08. The infrastructure identified in GI-2003-2 consists of the following:
 - a. Construct a new Corner Point Substation 40 miles east of Smoky Hill connecting to the PSCo Pawnee to Daniels Park 230 kV transmission line.
 - b. Construct a new 63 mile 230 kV line with 345 kV specifications from Corner Point to Daniels Park.
3. GI-2003-3: 750 MW Coal fired generator connected at Comanche Station and its associated infrastructure with a proposed ISD of 10/09. The infrastructure identified in GI-2003-3 consists of the following:
 - a. 345 kV yards at Comanche Station and Daniels Park Substation
 - b. Two new 122 mile 345 kV lines from Comanche Station to Daniels Park Substation.

As an NR request, the proposed generation was scheduled to the Denver Metro Area and Southeast Colorado peaking units.

At this Feasibility Study stage, the 150 MW wind farm was modeled as two (2) 75 MW conventional generators with a 0.9 pu lag power factor and a 0.95 pu lead power factor capability (+25/-36.5 MVAR) to simulate the VAR requirements of the generators. This is on the assumption that Customer will be using the GE 1.5 MW DFIG turbines that will have power factor and voltage control capability, as proposed and stated in their request.

As previously stated, the Customer to PSCo point of interconnection (POI) will be located at PSCo's Pawnee Station 230 kV switch yard, terminating the Customer's radial 18 to 20 mile 230 kV line constructed from the Customer's

wind turbine generation facility collector site to the PSCo Pawnee Station. Customer provided all the impedance data for their interconnecting radial 230 kV transmission line and their 230/34.5 kV step-up transformer.

Power Flow Study Results and Conclusions

Energy Resource (ER) Study Results:

The ER results were determined by using PTI's MUST program for performing power transfer limit analysis, and utilizing a PSS/E powerflow model.. The case included GI-2003-1, a 300 MW Wind Farm connecting at Pawnee Station along with it's associated infrastructure, with TOT 3 at 1470 MW, and showed that this wind project could inject 62 MW of power into the PSCo transmission system before network upgrades are constructed. The amount that the wind project can inject into the PSCo is directly related to the loading of the TOT 3 interface as well as other current generation currently dispatched at Pawnee Station and at nearby IPP's. For higher levels of TOT 3 there will be less injection capability is and similarly for lower levels of TOT 3 more injection capacity will be available. Also it should be noted that if any Pawnee area generation is off-line or reduced, more injection capability would be available. Appendix B shows the MUST transfer level results determining the 62 MW limit at 1470 MW TOT 3 loading. This level was also confirmed using a PSS/E saved case. The cost of the interconnecting facilities at Pawnee Station is \$625,000 and will take at least 9 months from the signing of an Interconnection agreement (IA) to complete construction.

Network Resource (NR) Study Results:

The NR study determined the network upgrades that will be required to accept the full 150 MW from the proposed wind farm for the conditions studied,. As stated earlier, the amount that can be injected into the PSCo transmission system is dependent upon the loading of the TOT 3 interface study examined 150 MW injections with TOT 3 at the 1470 MW level. Appendix C at the end of this document will show the MUST single contingency analysis study results that determine the need for infrastructure along with a contingency comparison table for the requests ahead of this one in the queue.

To determine the network upgrades the 2006 case from the ER evaluation was used and the proposed Ft. Morgan 150 MW Wind Farm was set at full 150 MW output along with the generation in the Pawnee area modeled at full output. Laramie River Station in Southern Wyoming was also dispatched so

that it was at its full capacity. With the wind generation dispatched to replace Cherokee Station generation, heavy loading occurs on the PSCo 230 kV system south of Ft. Lupton Station. For the loss of the Ft. Lupton Station to JL Green 230 kV line, the Ft. Lupton Station to Henry Lake line overloads 105% of its 435 MVA rating. Also the 230 kV line section from Henry Lake Substation to Riverdale Substation is at 100% of its rating

When including those requests higher in the Interconnection queue, the 2010 case showed that a Ft. Lupton Station to Henry Lake contingency will produce overloads as high as 112% for the Ft. Lupton Station to JL Green section and 110% for the JL Green to Washington line section. Other less severe overloads also occur for the loss of one of the three PSCo 230 kV lines exiting from Ft. Lupton Station south to Cherokee Station. To relieve the overloading conditions, network upgrades are required.

Coincident with the December 2006 interconnection, an uprate of the 230 kV line from Ft. Lupton Station-Henry Lake Substation-Riverdale Substation-Cherokee Station from 435 MVA to at least 460 MVA will be required. The estimated cost for this would be approximately \$153,000 and consists of installing double 1272 kCMIL ACSR jumpers on the equipment at Cherokee Station and Riverdale Substation.

By October 2008, the required network upgrades include converting the existing PSCo 28 mile Ft. Lupton Station to Platte Valley to Cherokee Station 115 kV line to 230 kV operation with an 800 MVA capacity. A system one-line diagram showing this entire infrastructure can be found below in Figure 1. Appendix D shows the one-line diagrams of the substations and their required changes.

The 115 kV to 230 kV conversion will be required before GI-2003-2 goes in service with a proposed ISD of 10/08. As mentioned earlier there are three 230 kV lines leaving Ft. Lupton Station and terminating at Cherokee Station and they are:

- Ft. Lupton Station – JL Green – Washington - Glenn – Cherokee Station
- Ft. Lupton Station – Henry Lake Substation– Riverdale Substation- Cherokee Station
- Ft. Lupton Station – Green Valley Station – Barr Lake Station – Reunion Substation– Cherokee Station

Powerflow studies that have generators GI-2003-1 (Brush 300 MW Wind Farm) and GI-2003-2 (Buick 500 MW Coal) and their associated infrastructure

show that for contingency of the line section from Ft. Lupton Station to JL Green overloads occur on the Ft. Lupton Station – Henry Lake Substation– Riverdale Substation- Cherokee Station line as much as 105% of the 435 MVA rating. Likewise for a contingency of the Ft. Lupton Station to Henry Lake Substation line, the Ft. Lupton Station – JL Green Substation – Washington Substation- Glenn Substation – Cherokee Station line overloads as much as 112% in addition to the Ft. Lupton Station 230/115 kV 280 MVA rated autotransformer overloading 108%. This results in the need to convert the 115 kV line from Ft. Lupton Station to Cherokee Station to 230 kV and convert the tapped Platte Valley Substation to 230 kV operation. With this upgrade in the powerflow studies, the above contingency overloads are alleviated.

Short Circuit Study Results

The short circuit analysis at Pawnee Station consisted of faulting the 230kV bus at Pawnee Station with three-phase and phase to ground faults. Previous studies show that the type of wind turbines specified by the Customer, provide little to no fault current. To exaggerate the fault current, the wind turbines were modeled as conventional generators using impedances supplied from the power flow studies. More detailed short circuit models, and associated possible Customer generation fault contribution (or lack thereof) will need to be addressed in later studies, such as the Interconnection System Impact Study (SIS), and the following Interconnection Facilities Study (IFS).

The fault currents are listed below.

Before the addition of the proposed Ft. Morgan 150MW Wind Farm (GI-2004-1) Wind Farm:


<u>Location</u>	<u>3 Phase</u>	<u>Single Phase</u>
Pawnee	23,625A	26,079A
Ft. Lupton	30,544A	26,033A
Smoky Hill	20,317A	21,134A

Before the addition of the proposed Ft. Morgan 150MW Wind Farm (GI-2004-1) Wind Farm:

<u>Location</u>	<u>3 Phase</u>	<u>Single Phase</u>
Pawnee	23,668A	26,114A
Ft. Lupton	30,552A	26,037A
Smoky Hill	27,103A	24,031A
Ft. Morgan Wind Farm	699A	32A

The fault current at these substations is within the 40kA rating of the breakers; therefore, the 150 MW Ft. Morgan Wind Farm and associated infrastructure will not cause fault current to exceed the circuit breaker ratings.

Figure 1
Pawnee Area - 2006



Costs Estimates and Assumptions:

To provide an interconnection and delivery for the Customer requested generation at the PSCo Pawnee Station; network upgrades must be made on the PSCo transmission system.

The estimated indicative total cost for the PSCo network upgrades is:

\$24,373,000

The estimated cost shown is an “indicative” (+/-30%) preliminary budgetary cost in 2006 dollars and is based upon typical construction costs for previously performed similar construction. These estimated costs include all applicable labor and overheads associated with the engineering, design, and construction of these new PSCo facilities. This estimate does not include any costs for any Customer-owned, supplied, and installed equipment and associated design and engineering. This estimate also does not include any costs that may be required for other entities’ systems.

The following lists the improvements required to accommodate the interconnection and the delivery of the proposed 150 MW facility. The cost responsibilities associated with these facilities shall be handled as per current FERC guidelines.

System Improvements (subject to change upon more detailed analysis):**PSCo Interconnection Facilities**

<u>Substation</u>	<u>Description</u>	<u>Cost</u>
Pawnee Station	Interconnect Customer’s 230 kV line, which will connect to the far west bay of the 230 kV switchyard. The new equipment required includes: • a new 230 kV 3000 A, 50 kA circuit breaker • 230 kV bi-directional revenue metering • two 230 kV switches • required steel supporting structures • associated control and relaying changes and additions. (See one-line in Appendix D)	\$550k

	Transmission line relocation	\$55k
	Siting and Land Rights for misc. permits	\$20k
	Total Cost	\$625k

PSCo Network Upgrades required to deliver the proposed 150 MW as an NR Request

2006 Additions

Substation	Description	Cost
Cherokee Station and Riverdale Substation	Install two (2) 1272 kCMIL ACSR jumpers from the incoming/outgoing transmission lines to the substation bus work, in addition to associated control and relaying changes and additions. (See one-lines in Appendix D)	\$83k
	Transmission Line Survey	\$50k
	Siting and Land Rights for misc. permits	\$20k
	Total Cost	\$155k

2008 Additions

	Description	Cost
Ft. Lupton Station	New 230 kV 2000 Amp Line Terminal to Cherokee Station via Platte Valley Substation which will be located on the far west bay of the 230 kV switchyard sharing the middle circuit breaker with one of the Ft. St. Vrain lines. The following equipment will be required: - one (1) 230 kV 3000 amp 50 kA circuit breaker - two (2) 230 kV switches - misc. supporting steel - electrical bus work - associated metering control and relaying (See One-line in Appendix D)	\$665k
Platte Valley Substation	Convert this Tri-State/Untied Power 115 kV delivery point to 230 kV operation. The	\$2,961k


	Description	Cost
	following equipment will be required: • two (2) 230 kV 2000 amp circuit breakers • two (2) 230 kV 1200 amp circuit switchers • two 230/13 kV, 25 MVA transformers • misc. supporting steel • electrical bus work • associated metering, control and relaying (See One-line in Appendix D)	
Cherokee Station	New 230 kV 2000 Amp Line Terminal to Ft. Lupton via Platte Valley Substation which will be located on the far west bay of the 230 kV switchyard sharing the middle circuit breaker with one of the Ft. St. Vrain lines. The following equipment will be required: • one (1) 230 kV 3000 amp 50 kA circuit breaker • two (2) 230 kV switches • misc. supporting steel • electrical bus work • associated metering control and relaying (See One-line in Appendix D)	\$669k
Transmission	Convert the existing 115 kV line from Ft. Lupton Station to Cherokee Station via Platte Valley to 230 kV operation.	\$18,600k
Siting and Permitting	Obtain necessary siting, permits, and ROW as required	\$700k
	TOTAL COST	\$23,595k
	TOTAL COST ALL PROJECTS	\$24,373k

Assumptions:

- Infrastructure associated with Interconnection Request GI-2003-1 is assumed to be constructed (See previous description) and it was determined that these network upgrades required a minimum of 27 months to complete following the execution of and IA. The feasibility study report for GI-2003-1 is available via RMAO.com.
- PSCo (or its contractor) crews will perform all construction and wiring associated with PSCo-owned and maintained equipment.
- The estimated time for design and construction of PSCo interconnection facilities at Pawnee Station is at least 9 months and is completely independent of GI-2003-1.
- The estimated time for design and construction for the PSCo network upgrades is at least 24 months after authorization to proceed has been received, and based upon other identified assumptions for Siting and Land Rights, and Transmission (see below).
- The last span into Pawnee Station from the Customer owned 230 kV line will be a slack span between the PSCo substation dead-end and the Customer's last structure, which is assumed to be a dead-end tangent structure.
- New Ft. Lupton Station-Platte Valley-Cherokee Station 230 kV line has a two conductor bundled 954 ACSR conductors per phase. Rebuild is constructed within existing ROW with daily outages and rebuilt one section at a time.
- A siting study will not be required if constructed in existing ROW
- Permitting to take at least 16 months and will be difficult in obtaining permits through six (6) local jurisdictions. It is also anticipated that a Certificate of Public Convenience and Necessity (CPCN) will be required from Colorado Public Utility Commission (CPUC).
- Minimal additional ROW required and available to rebuild.
- No land requirements for substations

APPENDIX A TOT 3 DETAILS

36. TOT 3



Item 1-96

Revised February 2003

36. TOT 3

Accepted Rating ☒
Existing Rating ☐
Other ☐

Location:	Border between Northeast Colorado and Southeast Wyoming														
Definition:	Sum of the flows on the following transmission lines: <table border="0"> <tr> <td><u>Line</u></td><td><u>Metered End</u></td></tr> <tr> <td>Archer-Ault 230 kV</td><td>Archer</td></tr> <tr> <td>Laramie River-Ault 345 kV</td><td>Laramie River</td></tr> <tr> <td>Laramie River-Story 345 kV</td><td>Laramie River</td></tr> <tr> <td>Cheyenne-Rockport 115 kV</td><td>Cheyenne</td></tr> <tr> <td>Sidney-Sterling 115 kV</td><td>Sidney</td></tr> <tr> <td>Sidney-N. Yuma 230 kV</td><td>Sidney</td></tr> </table>	<u>Line</u>	<u>Metered End</u>	Archer-Ault 230 kV	Archer	Laramie River-Ault 345 kV	Laramie River	Laramie River-Story 345 kV	Laramie River	Cheyenne-Rockport 115 kV	Cheyenne	Sidney-Sterling 115 kV	Sidney	Sidney-N. Yuma 230 kV	Sidney
<u>Line</u>	<u>Metered End</u>														
Archer-Ault 230 kV	Archer														
Laramie River-Ault 345 kV	Laramie River														
Laramie River-Story 345 kV	Laramie River														
Cheyenne-Rockport 115 kV	Cheyenne														
Sidney-Sterling 115 kV	Sidney														
Sidney-N. Yuma 230 kV	Sidney														
Transfer Limit:	North to South: 1605 MW (Maximum) South to North: Not defined Depending on local generation levels, DC tie levels and direction, the real-time rating can range between a maximum of 1605 W and a minimum of 843 MW. Typically, the real-time rating is calculated dynamically and updated every minute based on Table 1B.														
Critical Disturbance that limits the transfer capability:	The critical disturbances and limiting elements vary with the various scenarios. Reference Table 1B for further information.														
When:	Rating was first established in 1981. The current rating was established in July 1999 with publication of the "Comprehensive Progress Report for the Revised Rating of the TOT 3 Transfer Path." The study was conducted by Western and the revised rating was jointly proposed by: Western Area Power Administration (WAPA) - Loveland Tri-State Generation & Transmission Association, Inc. (TSGT) Public Service Company of Colorado (PSC) Basin Electric Power Cooperative (BEPC)														
System Conditions:	This rating is independent of transfer levels between major areas of WECC. The transfer limit is impacted by local area generation and the direction and magnitude of DC tie flows. Historically, the flows have all been north to south across the path. Under certain operating conditions when TOT 3 is loaded to its limit, the TOT 5 capability cannot be used since additional schedule on TOT 5 will overload TOT 3.														

Revised February 2000

Study Criteria:	(Summary) <u>System intact:</u> • Per unit voltages between 0.95 p.u. and 1.05 p.u. • All lines and transformers loaded to less than continuous rating. <u>Single contingency outage conditions:</u> • Per unit voltages between 0.90 p.u. and 1.10 p.u. • All lines loaded to less than 15-minute emergency ratings. • All transformers loaded to less than 30-minute emergency ratings. • Transient voltage swings down to 0.7 p.u. permitted.
Remedial Actions Required:	Remedial actions are required to achieve the rated transfer capability. Following an outage, all overloaded lines and transformers must have their loadings reduced to continuous ratings within 15 minutes. This is accomplished by reducing schedules and adjusting generation.
Formal Operating Procedure:	There is a formal operating procedure dated November 1999. WAPA-Loveland is the operating agent and uses real-time flows to monitor the path.
Allocation:	The transfer capability of the path is divided between WAPA, Missouri Basin Power Project (MBPP), Public Service Company of Colorado (PSC), and Tri-State Generation & Transmission (TSGT). TSGT and BEPC are members of MBPP.
Interaction w/Other Transfer Paths:	None
Contact Person:	Thu-Hong Tran Western Area Power Administration Rocky Mountain Region P. O. Box 3700 Loveland, CO 80539-3003 (970) 461-7404 (970) 461-7213 - fax trant@wapa.gov

APPENDIX B

MUST TRANSFER REPORT

AC FCITC Single Study - TOT 3 at 1470 MW

*** MUST 6.01 *** TUE, JUN 08 2004 9:54 ***
06HS- GI-2003-1 IN SERVICE; FROM 06 BASE...06 BUDGET REV 11

Subsys.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\NECO.SUB
Monit.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\NECO.MON
Contin.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\NECO.CON
Exclud.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\GI-2003-1A.exc

Study transfer level - 200.0 MW. Total violations: 1711

First violation - 6.0 MW.

Study transfer. From PAWNEE To DENVER . Transfer level - 200.0 MW

AC	DC	Delta L: Limiting constraint	PreShift	PostShf	AC_TDF	DC_TDF
FCITC	FCITC	FCITC C: Contingency description	Ncon	MVA/MW	MVA/MW	Rating
62.4	6.0	56.4 L:70192 FTLUPTON 230 70605 HENRYLAK 230 1	430.6	435.2	435.0	0.07447
		C:70192 FTLUPTON 230 70529 JLGREEN 230 1	192			0.07049
		Open 70192 FTLUPTON 230 70529 JLGREEN 230 1				
85.7	44.0	41.7 L:70192 FTLUPTON 230 70605 HENRYLAK 230 1	429.0	435.3	435.0	0.07444
		C:70461 WASHINGT 230 70529 JLGREEN 230 1	320			0.07049
		Open 70461 WASHINGT 230 70529 JLGREEN 230 1				
165.5	134.5	31.0 L:70311 PAWNEE 230 73192 STORY 230 1	606.1	575.6	576.0	-0.18426
Removed		C:73012 AULT 345 73108 LAR.RIVR 345 1	394			0.18203
		Open 73012 AULT 345 73108 LAR.RIVR 345 1				
122.6	138.4	-15.8 L:70006 BRSHWIND 230 70007 BRSHWIND134.5 1	151.9	167.1	167.0	0.12357
		C:73034 BURL PSC 115 73209 WANIBETP 115 1	428			-0.12282

Open 73034 BURL PSC 115 73209 WANIBETP 115 1

122.6 138.4 -15.8 L:70006 BRSHWIND 230 70007 BRSHWIND134.5 1 151.9 167.1 167.0 0.12357 -0.12282

C:73034 BURL PSC 115 73485 BURL KC 115 1 429

Open 73034 BURL PSC 115 73485 BURL KC 115 1

APPENDIX C

MUST CONTINGENCY REPORTS



Branch Violations - 2006 Cases

*** MUST 6.01 *** TUE, MAY 04 2004 15:07 ***
2006HS-BUDGET-PSC-REV11-RAL FRM 2006HS-BUDGET-PSC-REV10-RAL
SLACK=COMAN 1 (70119), CHEROK3=160, OPEN MIDWAYPS-MIDWAYBR 115

Subsys.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\NECO.SUB
Monit.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\NECO.MON
Contin.File S:\LDC-LI\Tra\2Jim\TRANSMISSION REQUESTS\Pacific Power Marketing\Cases\PSSE\MUST FILES\NECO.CON
Exclud.File None

***** Report on violations *****

Branches with MVA flow more than 100.0 % of nominal rating

From bus	**	**	To bus	**	CKt	Tp	Rating	Loading%	Loading%	Loading%	Loading%	Contingency
70469 WELD	46.0	70470 WELD	PS 115 T2			TR	46.7	111.3	111.3	111.3	111.3	** Base Case **
70149 DENVTM	230	70177 ELAT13	230 1			LN	300.0	<100%	107.7	120.8	70018 SODALAKE 230 70266 LOOKOUT 230 1	
70264 LITTLE2	115	70483 MARTN1TP	115 1			LN	135.0	122.0	125.0	122.6	70037 ARAPAHOB 115 70165 ENGLE3TP 115 1	
70463 WATERTON	115	70483 MARTN1TP	115 1			LN	135.0	136.9	139.1	140.3	70037 ARAPAHOB 115 70165 ENGLE3TP 115 1	
70149 DENVTM	230	70177 ELAT13	230 1			LN	300.0	<100%	100.1	115.8	70038 ARAPAOE 230 70137 DAKOTA 230 1	
70087 CAPHILL1	115	70300 NORTH547	115 1			LN	130.0	117.9	110.0	112.3	70039 ARGO 115 70108 CHEROKEE 115 1	
70087 CAPHILL1	115	70300 NORTH547	115 1			LN	130.0	109.3	101.8	103.8	70039 ARGO 115 70323 PLATTEPS 115 1	
70087 CAPHILL1	115	70300 NORTH547	115 1			LN	130.0	102.7	<100	<100%	70041 ARVADA 115 70108 CHEROKEE 115 1	
70149 DENVTM	230	70177 ELAT13	230 1			LN	300.0	<100%	107.8	115.9	70046 BUCKLEY2 230 70396 SMOKYHIL 230 1	
70149 DENVTM	230	70177 ELAT13	230 1			LN	300.0	<100%	104.2	112.2	70046 BUCKLEY2 230 70491 TOLGATE 230 1	
70149 DENVTM	230	70177 ELAT13	230 1			LN	300.0	<100%	101.7	112.5	70048 GREENVAL 230 70393 SKYRANCT 230 1	
70087 CAPHILL1	115	70300 NORTH547	115 1			LN	130.0	111.4	104.5	106.7	70073 CALIFOR1 115 70075 CALIFOR3 115 1	

70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	122.0	114.8	117.4	101.1	70073	CALIFOR1	115	70299	NORTH542	115	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	103.0	<100%	<100%	<100%	70074	CALIFOR2	115	70075	CALIFOR3	115	1
70073	CALIFOR1	115	70299	NORTH542	115	1	LN	137.0	113.3	110.1	112.8	108.6	70087	CAPHILL1	115	70215	HARRISPS	115	1
70073	CALIFOR1	115	70299	NORTH542	115	1	LN	137.0	107.0	101.8	104.2	<100%	70087	CAPHILL1	115	70300	NORTH547	115	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	105.2	102.0	104.4	100.4	70088	CAPHILL2	115	70148	DENVTM	115	1
70035	ARAP4	13.8	70037	ARAPAHOB	115	U4	TR	120.0	<100%	<100%	100.2	<100%	70106	CHEROKEE	22.0	70108	CHEROKEE	115	U4
70073	CALIFOR1	115	70299	NORTH542	115	1	LN	137.0	102.6	101.1	104.5	105.8	70107	CHEROKEE	230	70324	LACOMBE	230	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	117.0	114.4	118.8	121.1	70107	CHEROKEE	230	70324	LACOMBE	230	1
70065	BROMFLD1	115	70382	SEMPER	115	1	LN	134.8	122.8	124.9	125.8	122.9	70108	CHEROKEE	115	70174	FEDERT1	115	1
70073	CALIFOR1	115	70299	NORTH542	115	1	LN	137.0	111.5	106.4	108.7	104.2	70108	CHEROKEE	115	70276	MAPLETO1	115	1
70088	CAPHILL2	115	70148	DENVTM	115	1	LN	131.0	<100%	<100%	101.7	<100%	70108	CHEROKEE	115	70276	MAPLETO1	115	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	122.0	115.0	117.5	111.6	70108	CHEROKEE	115	70299	NORTH542	115	2
70121	COMANCHE	115	70122	COMANCHE	230	A1	TR	176.0	101.9	107.1	105.5	<100%	70121	COMANCHE	115	70122	COMANCHE	230	A2
70121	COMANCHE	115	70122	COMANCHE	230	A2	TR	185.0	<100%	102.1	100.6	<100%	70121	COMANCHE	115	70122	COMANCHE	230	A2
70149	DENVTM	230	70177	ELATI3	230	1	LN	300.0	<100%	<100%	107.3	122.8	70137	DAKOTA	230	70149	DENVTM	230	1
70149	DENVTM	230	70177	ELATI3	230	1	LN	300.0	<100%	<100%	102.0	117.0	70139	DANIELPK	230	70311	PAWNEE	230	1
73031	BRUSHTAP	115	73305	EFMORGRP	115	1	LN	121.7	<100%	<100%	100.1	<100%	70139	DANIELPK	230	70311	PAWNEE	230	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	109.3	101.8	103.8	<100%	70148	DENVTM	115	70323	PLATTEPS	115	1
70073	CALIFOR1	115	70299	NORTH542	115	1	LN	137.0	<100%	<100%	101.8	103.1	70149	DENVTM	230	70324	LACOMBE	230	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	113.0	110.6	114.9	117.3	70149	DENVTM	230	70324	LACOMBE	230	1
70463	WATERTON	115	70483	MARTN1TP	115	1	LN	135.0	100.7	102.2	103.0	100.3	70165	ENGLE3TP	115	70263	LITTLET1	115	1
73031	BRUSHTAP	115	73305	EFMORGRP	115	1	LN	121.7	<100%	<100%	100.6	100.6	70192	FTLUPTON	230	70311	PAWNEE	230	1
73031	BRUSHTAP	115	73305	EFMORGRP	115	1	LN	121.7	<100%	<100%	100.6	100.6	70192	FTLUPTON	230	70311	PAWNEE	230	2
70192	FTLUPTON	230	70605	HENRYLAK	230	1	LN	435.0	<100%	<100%	105.4	<100%	70192	FTLUPTON	230	70529	JLGREEN	230	1
70362	RIVERDAL	230	70605	HENRYLAK	230	1	LN	435.0	<100%	<100%	100.3	<100%	70192	FTLUPTON	230	70529	JLGREEN	230	1
70087	CAPHILL1	115	70300	NORTH547	115	1	LN	130.0	106.3	101.9	103.1	<100%	70259	LEETSDAL	115	70260	LEETSDAL	230	T4
70444	VALMONT	115	70447	VALMONT	230	T7	TR	280.0	<100%	101.3	101.8	<100%	70266	LOOKOUT	230	70570	PLINENDSS	230	1
70073	CALIFOR1	115	70299	NORTH542	115	1	LN	137.0	107.0	101.9	104.1	<100%	70276	MAPLETO1	115	70300	NORTH547	115	1
70310	PAWNEE	22.0	70311	PAWNEE	230	1B	TR	364.0	137.9	140.0	142.8	139.9	70310	PAWNEE	22.0	70311	PAWNEE	230	1A
70310	PAWNEE	22.0	70311	PAWNEE	230	1A	TR	364.0	137.9	140.0	142.8	139.9	70310	PAWNEE	22.0	70311	PAWNEE	230	1B
70149	DENVTM	230	70177	ELATI3	230	1	LN	300.0	<100%	<100%	113.7	128.2	70311	PAWNEE	230	70343	QUINCY	230	1
73031	BRUSHTAP	115	73305	EFMORGRP	115	1	LN	121.7	<100%	<100%	101.5	<100%	70311	PAWNEE	230	70343	QUINCY	230	1

73023	BIJOUTAP	115	73379	FMWEST	115	1	LN	80.0	<100%	101.9	101.0	101.1	70311	PAWNEE	230	73192	STORY	230	1			
73031	BRUSHTAP	115	73305	EFMORGTP	115	1	LN	121.7	<100%	119.3	119.9	119.6	70311	PAWNEE	230	73192	STORY	230	1			
70149	DENVTM	230	70177	ELATI3	230	1	LN	300.0	<100%	<100%	<100%	100.9	70311	PAWNEE	230	73192	STORY	230	1			
70149	DENVTM	230	70177	ELATI3	230	1	LN	300.0	<100%	<100%	113.1	127.7	70343	QUINCY	230	70396	SMOKYHIL	230	1			
73031	BRUSHTAP	115	73305	EFMORGTP	115	1	LN	121.7	<100%	<100%	101.2	<100%	70343	QUINCY	230	70396	SMOKYHIL	230	1			
70149	DENVTM	230	70177	ELATI3	230	1	LN	300.0	<100%	<100%	101.7	112.5	70393	SKYRANCT	230	70528	SPRUCE	230	1			
70523	SULPHUR	115	70524	SULPHUR	230	T1	TR	168.0	105.1	108.5	106.4	108.9	70395	SMOKYHIL	115	70521	PEAKVIEW	115	1			
70192	FTTUPTON	230	70605	HENRYLAK	230	1	LN	435.0	<100%	<100%	104.9	<100%	70461	WASHINGT	230	70529	JLIGREEN	230	1			
70165	ENGLE3TP	115	70263	LITTLE1	115	1	LN	134.8	105.6	106.9	108.0	105.6	70463	WATERTON	115	70483	MARTIN1TP	115	1			
73211	WELD	LM	115	73212	WELD	LM	230	1	150.0	142.2	134.5	134.4	135.0	70471	WELD	PS	230	73212	WELD	LM	230	1
70570	PLNENDSS	230	70580	PLNENDNG13.8	U2		TR	100.0	119.9	121.7	121.7	121.7	70570	PLNENDSS	230	70580	PLNENDNG13.8	U1				
70570	PLNENDSS	230	70580	PLNENDNG13.8	U1		TR	100.0	119.9	121.7	121.7	121.7	70570	PLNENDSS	230	70580	PLNENDNG13.8	U2				
73043	CHEYENNE	115	73480	CROWCRK	115	1	LN	80.0	112.2	113.8	114.2	114.3	73008	ARCHER	115	73043	CHEYENNE	115	1			
73008	ARCHER	115	73043	CHEYENNE	115	1	LN	80.0	108.6	109.7	110.0	110.1	73008	ARCHER	115	73183	SKYLINE	115	1			
73008	ARCHER	115	73043	CHEYENNE	115	1	LN	80.0	142.7	144.4	144.8	114.3	73008	ARCHER	115	73480	CROWCRK	115	1			
70311	PAWNEE	230	73192	STORY	230	1	LN	576.0	<100%	105.5	100.6	101.2	73012	AULT	345	73108	LAR.RIVR	345	1			
73009	ARCHER	230	73190	STEGALL	230	1	LN	400.0	112.1	110.2	112.2	111.6	73012	AULT	345	73108	LAR.RIVR	345	1			
73023	BIJOUTAP	115	73379	FMWEST	115	1	LN	80.0	105.9	100.1	104.2	103.8	73012	AULT	345	73108	LAR.RIVR	345	1			
73024	BLKHLWTP	115	73552	AULT	115	1	LN	85.1	101.8	101.2	102.6	102.6	73012	AULT	345	73108	LAR.RIVR	345	1			
73031	BRUSHTAP	115	73305	EFMORGTP	115	1	LN	121.7	103.6	107.7	112.6	111.8	73012	AULT	345	73108	LAR.RIVR	345	1			
73145	NUNN	115	73552	AULT	115	1	LN	85.1	102.1	101.5	102.9	102.9	73012	AULT	345	73108	LAR.RIVR	345	1			
73179	SIDNEY	115	73180	SIDNEY	230	1	TR	167.0	100.2	<100%	<100%	<100%	73012	AULT	345	73108	LAR.RIVR	345	1			
73013	B.CK PS	115	73014	B.CK PS	230	T1	TR	224.0	<100%	110.1	110.1	110.1	73013	B.CK PS	115	73020	BEAVERCK	115	1			
73015	B.CK TRI	115	73020	BEAVERCK	115	1	LN	200.0	<100%	<100%	103.2	102.7	73013	B.CK PS	115	73020	BEAVERCK	115	1			
73023	BIJOUTAP	115	73379	FMWEST	115	1	LN	80.0	101.6	103.0	107.7	107.7	73020	BEAVERCK	115	73464	ADENA	115	1			
73031	BRUSHTAP	115	73305	EFMORGTP	115	1	LN	121.7	<100%	107.0	112.7	112.3	73020	BEAVERCK	115	73464	ADENA	115	1			
73098	KODAK	115	73211	WELD	LM	115	1	120.0	110.9	113.7	114.3	113.9	73026	BOYD	115	73027	BOYD	230	1			
73120	LOVE W	115	73124	LOVEWTP	115	1	LN	110.0	107.3	107.3	107.5	107.3	73026	BOYD	115	73118	LOVE E	115	1			
73008	ARCHER	115	73043	CHEYENNE	115	1	LN	80.0	119.8	121.4	121.8	121.9	73043	CHEYENNE	115	73480	CROWCRK	115	1			
73052	DRAKE RD	115	73198	TIMBERLN	115	1	LN	105.2	101.4	<100%	<100%	<100%	73051	DIXON CK	115	73149	OVERLAND	115	1			
73051	DIXON CK	115	73149	OVERLAND	115	1	LN	96.0	108.7	102.9	103.1	102.9	73052	DRAKE RD	115	73198	TIMBERLN	115	1			
73149	OVERLAND	115	73506	LAPORTAP	115	1	LN	96.0	108.7	102.8	103.1	102.9	73052	DRAKE RD	115	73198	TIMBERLN	115	1			



73098 KODAK 115 73211 WELD LM 115 1	LN	120.0	108.8	106.8	108.2	107.7	73078 HARMONY 230 73199 TIMBERLN 230 1
73023 BIJOUTAP 115 73379 FMWEST 115 1	LN	80.0	100.3	101.7	106.4	106.4	73088 HOYT 115 73464 ADENA 115 1
73031 BRUSHTAP 115 73305 EFMORGTP 115 1	LN	121.7	<100%	107.0	111.9	111.6	73088 HOYT 115 73464 ADENA 115 1
73115 LONGPEAK 115 73116 LONGPEAK 230 2	TR	168.0	117.7	119.0	118.1	118.0	73115 LONGPEAK 115 73116 LONGPEAK 230 1
73115 LONGPEAK 115 73116 LONGPEAK 230 1	TR	168.0	117.4	118.7	117.8	117.7	73115 LONGPEAK 115 73116 LONGPEAK 230 2
73048 DEL CTAP 115 73133 MEADOW 115 1	LN	154.0	109.9	111.0	111.0	110.7	73115 LONGPEAK 115 73196 TERRY 115 1
73113 LNGMNTNW 115 73133 MEADOW 115 1	LN	110.2	104.1	105.6	105.4	105.1	73115 LONGPEAK 115 73196 TERRY 115 1
73179 SIDNEY 115 73180 SIDNEY 230 1	TR	167.0	116.5	115.6	115.1	114.9	73143 N.YUMA 230 73180 SIDNEY 230 1
73166 REDWILLW 115 73208 WAGES 115 1	LN	55.0	106.9	105.2	105.5	105.5	73175 SANDHILL 115 73223 WRAY 115 1
73105 LAPORTE 115 73106 LAPORTE 230 1	TR	168.0	103.1	<100%	<100%	<100%	73198 TIMBERLN 115 73199 TIMBERLN 230 1
73384 BIRDSALE 115 73386 BIRDSALS34.5 1	TR	27.0	101.3	105.2	101.5	101.4	73382 BIRDSAL213.8 73386 BIRDSALS34.5 1
73384 BIRDSALE 115 73386 BIRDSALS34.5 1	TR	27.0	124.5	124.7	124.8	124.7	73383 BIRDSAL313.8 73386 BIRDSALS34.5 1
73396 DRAKE E 34.5 73398 DRAKE S 115 1	TR	67.0	118.6	118.8	118.8	118.8	73396 DRAKE E 34.5 73427 DRAKE 5 13.8 1
73409 KELKER W 115 73420 ROCKISLD 115 1	LN	132.9	100.2	<100%	<100%	<100%	73408 KELKER E 115 73409 KELKER W 115 1
73412 MIDWAYBR 115 73413 MIDWAYBR 230 A2	TR	100.0	103.7	110.2	111.4	108.7	73413 MIDWAYBR 230 73419 RD NIXON 230 1
73110 LIBERTY 115 73309 BARLOW 115 1	LN	60.0	100.1	<100%	<100%	<100%	73413 MIDWAYBR 230 73531 LINCOLNT 230 1
73023 BIJOUTAP 115 73379 FMWEST 115 1	LN	80.0	<100%	<100%	104.2	104.0	73413 MIDWAYBR 230 73531 LINCOLNT 230 1
79051 FLAGSTA 345 79024 FLAGSTAF 345 2	LN	747.0	118.7	118.6	118.5	118.5	79024 FLAGSTAF 345 79032 GLENCANY 345 &1
73384 BIRDSALE 115 73386 BIRDSALS34.5 1	TR	27.0	115.3	115.3	115.3	115.3	GEN.Outage:73383 BIRDSAL313.8
73396 DRAKE E 34.5 73398 DRAKE S 115 1	TR	67.0	109.2	109.0	109.0	108.8	GEN.Outage:73427 DRAKE 5 13.8

COLOR CODES
WESTERN FACILITIES
TRI-STATE FACILITIES
PSCO FACILITIES
PRPA FACILITIES
CSU FACILITIES
IREA FACILITIES

2010 Case Contingency Comparison

Element Loading				Case	2010 Comanche Base As per SIS Study (10w-a6-2g2)	2010 All Gen in queue w/o Ft. Morgan (10walligen5a)	2010 All Gen in queue with Ft. Morgan (10walligen5)	2010 with Buick and Pawnee Wind (10w-buick-b)	2010 with Buick, Pawnee Wind, and Ft. Morgan Wind (10w-buick-e)	Contingency		
#	From Bus	-kv- zon	#							From Bus	To Bus	
	--name--			CKT ID	rating	cont	load	cont	load	#	--name--	-kv- #
70353	READER	69 712 70352	READER	115	1	47	151%	153%	153%	151%	152%	70353
70353	READER	69 712 70352	READER	115	2	47	151%	153%	153%	151%	152%	70353
70005	BRUSHCPP	115 706 73013	B.CK PS	115	1	162	136%	113%	113%	134%	134%	70005
73391	CTTNWD N	115 757 73410	KETTLECK	115	1	133	129%	128%	129%	117%	117%	73389
70470	WELD PS	115 706 70471	WELD PS	230	2	150	127%	112%	112%	115%	115%	70439
70132	CTY LAJ	69 712 70248	LAJUNTAT	69	1	39	124%	124%	124%	125%	125%	70247
79029	FLAMGORG	69 790 79026	FLAMGORG	138	1	19	123%	123%	123%	123%	123%	70005
70275	MANZANOL	69 712 70419	MANZANOL	115	1	25	122%	118%	118%	118%	120%	70060
73211	WELD LM	115 754 73212	WELD LM	230	1	150	122%	130%	130%	126%	125%	70470
70005	BRUSHCPP	115 706 73013	B.CK PS	115	2	187	118%	98%	98%	133%	133%	70005
70054	BMONT TP	69 712 70455	W.STATON	69	1	47.8	117%	118%	118%	119%	119%	70042
70308	PALMER	115 704 73414	MONUMENT	115	1	133	117%	112%	113%	99%	99%	73477
73409	KELKER W	115 757 73420	ROCKISLD	115	1	120	115%	115%	115%	114%	115%	73408
70242	KENDRICK	115 700 70045	BANCROFT	115	1	192	113%	113%	113%	114%	114%	70400
70042	ASPEN TP	69 712 70051	BLENDE	69	1	47.8	112%	112%	112%	112%	112%	70054
70400	SODALAKE	115 700 70023	ALLISON	115	1	189	111%	112%	112%	113%	113%	70242
70354	RIDGE	115 700 70355	RIDGE	230	2	100	110%	109%	109%	109%	109%	70354
70524	SULPHUR	230 700 70523	SULPHUR	115	1	168	109%	105%	105%	112%	113%	70395

Page 28 of 38

70463	WATERTON	115 700 70464	WATERTON 230	1	100	94%	99%	99%	<90%	91%	70463	WATERTON 115 70464	WATERTON 230
73078	HARMONY	230 754 73199	TIMBERLN 230	1	472.1	94%	<90%	<90%	91%	92%	73011	AULT 230 70474	WINDSOR 230
73404	FOUNTAIN	115 757 73417	RD_NIXON 115	1	159	94%	94%	94%	94%	94%	73407	KELKER 230 73409	KELKER W 115
70087	CAPHILL1	115 700 70300	NORTH547 115	1	150	94%	<90%	<90%	<90%	93%	70108	CHEROKEE 115 70299	NORTH542 115
70250	LAJUNTAW	69 712 70249	LAJUNTAW 115	1	25	93%	<90%	<90%	<90%	93%	70275	MANZANOL 69 70419	MANZANOL 115
70108	CHEROKEE	115 700 70298	NORTH PS 115	1	170.9	93%	92%	92%	93%	93%	70108	CHEROKEE 115 70277	MAPLETO2 115
73305	EFMORGTP	115 752 73379	FMWEST 115	1	121	93%	92%	92%	93%	93%	73192	STORY 230 70311	PAWNEE 230
70395	SMOKYHIL	115 700 70396	SMOKYHIL 230	1	150	93%	94%	94%	93%	<90%	70395	SMOKYHIL 115 70396	SMOKYHIL 230
73013	B.CK PS	115 706 73020	BEAVERCK 115	1	319	93%	<90%	<90%	100%	100%	73192	STORY 230 70311	PAWNEE 230
70231	HOPKINS	115 708 79003	BASALT 115	1	66.9	92%	90%	90%	NA	NA	70654	COMANCHE 345 70777	COMAN 3 24
70108	CHEROKEE	115 700 70174	FEDERHT1 115	1	186	91%	90%	90%	94%	<90%	70108	CHEROKEE 115 70175	FEDERHT2 115
70108	CHEROKEE	115 700 70175	FEDERHT2 115	2	186	91%	90%	90%	90%	<90%	70108	CHEROKEE 115 70174	FEDERHT1 115
70444	VALMONT	115 703 70447	VALMONT 230	1	280	91%	<90%	<90%	<90%	<90%	70266	LOOKOUT 230 70570	PLNENDSS 230
70139	DANIELPK	230 700 70601	DANIELPK 345	2	560	<90%	95%	96%	NA	NA	70139	DANIELPK 230 70601	DANIELPK 345
70139	DANIELPK	230 700 70601	DANIELPK 345	3	560	<90%	95%	96%	NA	NA	70139	DANIELPK 230 70601	DANIELPK 345
70139	DANIELPK	230 700 70601	DANIELPK 345	1	560	<90%	95%	96%	NA	NA	70139	DANIELPK 230 70601	DANIELPK 345
70442	UNIVERS2	115 700 70036	ARAPAHOA 115	1	150	<90%	92%	92%	<90%	<90%	70259	LEETSDAL 115 70260	LEETSDAL 230
70352	READER	115 712 70483	BURNTMIL 115	1	99.6	<90%	91%	91%	<90%	<90%	70339	PUEBLO 115 70352	READER 115
70539	CHAM48TH	230 700 70538	CHAM48TH 115	1	280	<90%	103%	102%	<90%	<90%	70048	GREENVAL 230 70047	BARRLAKE 230
70463	WATERTON	115 700 70464	WATERTON 230	3	100	NA	100%	101%	NA	NA	70463	WATERTON 115 70464	WATERTON 230
70192	FTLUPTON	230 706 70529	JLGREEN 230	1	435	<90%	93%	94%	108%	112%	70192	FTLUPTON 230 70605	HENRYLAK 230
70529	JLGREEN	230 706 70461	WASHINGTON 230	1	495	<90%	<90%	93%	106%	110%	70192	FTLUPTON 230 70605	HENRYLAK 230
70191	FTLUPTON	115 706 70192	FTLUPTON 230	1	280	<90%	96%	98%	105%	108%	70192	FTLUPTON 230 70529	JLGREEN 230
73073	GRANBYPP	69 755 73132	MCKENZIE 69	1	36	<90%	99%	98%	NA	NA	70654	COMANCHE 345 70777	COMAN 3 24
73132	MCKENZIE	69 755 73436	MARYLKS 69	1	33	<90%	96%	96%	NA	NA	70654	COMANCHE 345 70777	COMAN 3 24
70073	CALIFOR1	115 700 70299	NORTH542 115	1	150	<90%	<90%	<90%	104%	97%	70087	CAPHILL1 115 70215	HARRISPS 115
70087	CAPHILL1	115 700 70300	NORTH547 115	1	150	<90%	<90%	<90%	102%	<90%	70073	CALIFOR1 115 70299	NORTH542 115
70192	FTLUPTON	230 706 70605	HENRYLAK 230	1	435	<90%	<90%	<90%	101%	105%	70192	FTLUPTON 230 70529	JLGREEN 230
70605	HENRYLAK	230 706 70362	RIVERDAL 230	1	435	<90%	<90%	<90%	98%	102%	70192	FTLUPTON 230 70529	JLGREEN 230
70108	CHEROKEE	115 700 70299	NORTH542 115	2	170.9	<90%	<90%	<90%	91%	<90%	70087	CAPHILL1 115 70215	HARRISPS 115
70481	MONACO12	230 700 70212	GREENWD 230	1	439	<90%	<90%	<90%	90%	<90%	70396	SMOKYHIL 230 70046	BUCKLEY2 230

70539	CHAM48TH	230 700 70538	CHAM48TH 115	1	280	<90%	<90%	<90%	<90%	<90%	102%	107%	70528	SPRUCE	230 70396	SMOKYHIL 230
70250	LAJUNTAW	69 712 70249	LAJUNTAW 115	1	25	<90%	<90%	<90%	<90%	<90%	95%	95%	70254	LAMAR CO	230 70253	LAMAR CO 115
70395	SMOKYHIL	115 700 70396	SMOKYHIL 230	1	150	<90%	<90%	<90%	<90%	<90%	<90%	95%	70539	CHAM48TH	230 70538	CHAM48TH 115
70396	SMOKYHIL	230 700 70046	BUCKLEY2 230	1	435	<90%	<90%	<90%	<90%	<90%	<90%	94%	70481	MONACO12	230 70212	GREENWD 230

Color Code


Noticeable Load Increase
Aquila Equipment
CSU Equipment
TSGT Equipment
PSCO Equipment
IREA Equipment
WAPA or Other Equipment

APPENDIX D


ONE-LINES

Appendix D-1


Pawnee Station One-line




Appendix D-2 Ft. Lupton Station One-line



Appendix D-3 Platte Valley One-Line



Appendix D-4 Cherokee Station One-Line



APPENDIX E

PSCo Generation Interconnection Request Queue

GENERATION INTERCONNECTION REQUESTS

May 28, 2004

Queue Number	Date Received	Generation Type	Service Type	Location County/State	Interconnection Point Station or Line	Net Plant Max MW Sum Win	In-Service Date	Comments/Status/Reason not Completed
GI-2003-1	10/21/2003	Wind	Network Resource	Morgan Co., CO	Pawnee Substation	300 300	12/1/2006	Feasibility Study complete System Impact Study underway
GI-2003-2	11/3/2003	Coal	Network +Energy Resource	Elbert Co., CO	Smokey Hill-Pawnee 230kV line	500 500	6/1/2008	Feasibility Study complete System Impact Study underway
GI-2003-3	11/7/2003	Coal	Network Resource	Pueblo Co., CO	Comanche Substation	750 750	10/1/2009	Feasibility Study complete System Impact Study underway
GI-2003-4	11/11/2003	Wind	Network +Energy Resource	Laramie Co., WY	Ponnequin Substation	30 30	Q2-2004	Feasibility Study complete System Impact Study underway
GI-2003-5	12/29/2003	Coal	Network Resource	Morgan Co., CO	Pawnee Substation	750 750	10/1/2009	Request withdrawn 2/20/04
GI-2004-1	1/19/2004	Wind	Network +Energy Resource	Morgan Co., CO	Story Substation	150 150	12/31/2005	Feasibility Study underway
GI-2004-2	2/9/2004	Wind	Network +Energy Resource	Baca Co., CO	Lamar Substation	238 238	9/31/2005	Feasibility Study complete