

# **LAMAR BACK-TO-BACK DC LINK SYSTEM STUDIES Task 8 (Addendum)**

Prepared for  
**Xcel Energy**

By

Electranix Corporation  
107 – 865 Waverley St.,  
Winnipeg, MB, R3T 5P4  
Canada

Manitoba HVDC Research Centre Inc.  
244 Cree Crescent,  
Winnipeg, MB, R3J 3W1  
Canada

October 23, 2002

Project Leader: Garth Irwin  
Phone: +1 204 953 1831  
Fax: +1 204 953 1839  
e-mail: [gdi@electranix.com](mailto:gdi@electranix.com)

**Contributors:**

Alan Wang	– Manitoba HVDC Research Centre
Dennis Woodford	– Electranix Corporation
Alfred Lee	– Teshmont Consultants
Saif Imran	– Teshmont Consultants

# **Lamar Back-to-Back DC Link – Task 8 Addendum**

## **Final Report**

### **Executive Summary**

Garth Irwin  
Electranix Corporation, Winnipeg, Manitoba, Canada  
(204) 953-1831, [gdi@electranix.com](mailto:gdi@electranix.com)

October 23, 2002

### **Introduction**

The goal of Task 8 Addendum is to perform additional Loadflow and Dynamic Transient studies of the Lamar HVDC Back to Back system. The work in this report is an extension of the original Task 8 report (April 19, 2002), with the following specific changes and additions:

#### **Load Flow Studies:**

1. Addition of a sixth base case, which considers an import of 160 MW (from the wind farm) plus up to 210 MW from the DC link for a total import of 370 MW into the WECC system (previous base cases studied a maximum total import of 210 MW).
2. Add monitoring of incremental bus voltages during contingency analysis.
3. Tap changers are locked during contingency analysis (the previous study work allowed automatic tap changers to operate during contingencies, but manual tap changers were fixed).
4. An additional contingency has been added for the loss of one of the Comanche generators.

#### **Stability Studies**

5. Studies have been repeated with additional plots added of the angles of nearby generators at Comanche and Nixon.

This report includes all study results and conclusions from the previous round of studies, and from three study areas:

1. Load-flow Studies of the HVDC System and Golden Plains Wind Farm
2. Transient Stability Studies of the HVDC System
3. HVDC Electro-Magnetic Transients Studies (study results copied from original Task 8 Report)

## **Summary of Conclusions**

The new study results do not significantly change the conclusions presented in the earlier report. The specific incremental changes in this study (compared to the last study) are:

- The loss of a single Comanche generator does not result in any difficulties for any of the cases studied.
- The full import of 210 MW HVDC plus 160 MW wind farm (for a total of 370 MW into the WECC system) does not introduce any significant difficulties.
- The locking of tap changer settings during contingencies has minimal effect on the conclusions.
- The monitoring of incremental bus voltage deviations identifies largely the same contingencies as for the monitoring of the absolute voltages. The major exception was the loss of the Boone-Dot 115 kV line, which results in incremental voltages at Dot 115 kV bus, which are larger than 5% (this is a pre-existing problem before the DC system was added).

The overall conclusions (from the last report and this one) are summarized as follows:

## **Load Flow Study Results (Wind Farm and HVDC System)**

- The load flow studies indicate pre-existing undervoltage problems in the 115 kV system (near LajuntaW) if the Boone 230/115 transformer is lost (this transformer's tap control regulates voltages in the 115 system during normal operation). The addition of the HVDC system slightly improves the situation (by providing reactive power through the 115 kV system from Lamar), but does not prevent the undervoltages for this contingency.
- DC Power Order reductions must be performed if the Lamar-Boone 230 line is tripped.
- When exporting the full 210 MW, undervoltages near the Lamar 230 kV bus occur for many contingencies, unless an AC voltage control mode of the DC link is added.
- If an AC voltage control mode is added at the DC link, then full power can be imported or exported through nearly all single contingencies.

## **HVDC Transient Stability Results (HVDC System Only)**

- The AC filters of the HVDC link must be tripped after a blocking operation (or power order reduction) to prevent long-duration overvoltages and overloading of the CTY LAM 25 MW machine.
- All electro-mechanical oscillations are damped (the emergency block of the HVDC system was the largest step-disturbance possible in the vicinity of the Lamar bus).
- These studies have been backed up with detailed electro-magnetic transients (PSCAD) models. This was done to properly represent the HVDC system operating in the system with a low short circuit ratio and to study voltage regulation with more accuracy.

## **HVDC PSCAD Results (HVDC System Only)**

- All electro-mechanical oscillations in the studies performed were damped (using generic HVDC controls).
- The HVDC system showed an interaction with the 25 MW machine at CTY LAM, however the interactions were damped (using preliminary HVDC control models).
- Once the final HVDC control design is complete, a detailed study of the interactions between the HVDC system and nearby machines should be performed to see if a PSS damping controller is required (a provision for a PSS input is in the HVDC specification).
- The AC filters of the HVDC link must be tripped after a blocking operation (or power order reduction) to prevent long-duration overvoltages and overloading of the CTY LAM 25 MW machine.
- All voltages are within WECC undervoltage criteria and meet the TOV criteria in the HVDC specification (as long as AC filters are tripped during blocking of the HVDC system or during power order reductions).

## **Conclusions**

The addition of the Lamar HVDC Back to Back system (as per the design in the HVDC specification) will not have any adverse reactions on the WECC system, as long as operating procedures are followed for certain contingencies and AC voltage control is used for the DC link.

The only contingency that affected the system was for the loss of the Comanche - Boone 230 kV Line, while the WECC Colorado system was exporting 210 MW to SPP. This contingency created a 5% voltage deviation for busses between Boone and Lamar and undervoltages around 0.94 pu on the La Junta 115 kV buses.

All other system problems were base case violations with either the WestPlains or Tri-State systems in the study area.



# Lamar Back-to-Back DC Link – Task 8 Addendum – Final Report

<b><u>Table of Contents</u></b>	<b>Page</b>
Introduction	6
1) Load-flow Studies	7
- Results	10
- Discussion and Summary	13
2) Transient Stability Studies	15
- Results	16
3) Electromagnetic Transients Studies	18
- Results	19
Task 8 Addendum Conclusions	20
Acknowledgements	20
Appendix 1	Loadflow Bus Specification
Appendix 2	Loadflow Case Descriptions
Appendix 3	Loadflow Results
Appendix 4	Case 3 (Exporting 210 MW) Contingency 5 (Loss of Boone-Comanche 230 Line)
Appendix 5_1	Transient Stability Results (Base Case before DC Link is Added)
Appendix 5_2	Transient Stability Results (Importing of 210 MW)
Appendix 5_3	Transient Stability Results (Exporting of 210 MW)
Appendix 6	PSCAD Electromagnetic Transients Circuit
Appendix 7	PSCAD Electromagnetic Transients Results

## **Task 8 Addendum – Introduction**

The goal of Task 8 Addendum is to perform additional Loadflow and Dynamic Transient studies of the Lamar HVDC Back to Back system. The work in this report is an extension of the original Task 8 report (April 19, 2002), with the following specific changes and additions:

### **Load Flow Studies:**

1. Addition of a sixth base case, which considers an import of 160 MW (from the wind farm) plus up to 210 MW from the DC link (previous base cases studied a maximum total import of 210 MW).
2. Add monitoring of incremental bus voltages during contingency analysis.
3. Tap changers are locked during contingency analysis (the previous study work allowed automatic tap changers to operate during contingencies, but manual tap changers were fixed).
4. An additional contingency has been added for the loss of one of the Comanche generators.

### **Stability Studies:**

5. Studies have been repeated with additional plots added of the angles of nearby generators at Comanche and Nixon.

This report presents results and conclusions from three sets of studies:

1. Load-flow Studies of the HVDC System and Golden Plains Wind Farm
2. Transient Stability Studies of the HVDC System
3. HVDC Electro-Magnetic Transients Studies (study results copied from original Task 8 Report)

The previous Task 8 Final Report (April 19, 2002) included loadflow study results with and without a voltage regulating mode of the HVDC link. A recommendation of that report was to specify an overrating of the HVDC link by +50 MVARs, so it can be effective in regulating the Lamar 230 kV bus AC voltage. The loadflow studies in this report (Task 8 Addendum) only present the loadflow results with the AC voltage control capability of the HVDC link.

This report includes all study results and conclusions from the previous round of studies.

## **1) Load-flow Studies**

Load-flow studies were performed to ensure steady state voltages and power flows meet the NERC/WECC Planning Standards. The following study results include an AC voltage control mode of the DC link added (at the cost of additional +50/-20 MVAR reactive power, which is representative of regulating reactive power that might be available in the DC design).

This study differs from the last Task 8 Study in the following ways:

1. Addition of a sixth base case, which considers an import of 160 MW (from the wind farm) plus up to 210 MW from the DC link (previous base cases studied a maximum total import of 210 MW).
2. Add monitoring of incremental bus voltages during contingency analysis.
3. Tap changers are locked during contingency analysis (the previous study work allowed automatic tap changers to operate during contingencies, but manual tap changers were fixed).
4. An additional contingency has been added for the loss of one of the Comanche generators.

The new base case considers a total import of 370 MW into the WECC system (160 MW from the wind farm plus 210 from the DC system).

During the development of this base case, the contingency analysis was performed with all tap changers locked, all phase shifters locked, and all SVD (Switched Var Devices) locked in their pre-contingency states. Two of the contingency cases showed problems (low voltages caused by a nearby generator incorrectly consuming large amounts of reactive power) that were attributed to bugs in the PSLF program (these bugs were confirmed by Xcel Energy and the problematic cases sent to the developers of the PSLF program for investigation). It was discovered that allowing the SVD devices to operate during contingencies solved these problems and led to consistent results. This minor change in the solution algorithm was deemed to not significantly affect the results, since only switched reactor banks are present near the Lamar 230 kV bus, which were not on during the base case and did not switch on during the contingencies. The SVD devices were thus allowed to operate for the following cases, but the tap changers and phase shifters were locked for all contingencies.

## Load Flow Case List

Six base cases were analyzed, as summarized in Table 1:

Table 1 – Load Flow Case Descriptions			
Base Case #	Back-to-Back ( +ve from SPP to WECC ) (MW)	Wind Turbine (MW)	Change in WECC Generation (MW)
1 (Orig. Case)	0	0	0
2	210	0	-210
3	-210	0	210
4	50	160	-210
5	-210	160	50
6	210	160	-370

## Load Flow Data Modifications

A PSLF load flow data has been provided by XCEL Energy for this study (Case 05ha1sa.sav, received November 27, 2001). The following changes were made to the base system:

- The DC system has been represented as a generator (for load flow studies only) with an AC voltage control mode. It is represented as a generator that controls its terminal voltage to a set-point with reactive power limits of +50/-20 MVAR (the voltage set-point is usually 1.04 pu – the bus volts is not set to 1.05 pu, since the Ferranti effect can increase the bus volts above tolerance during contingencies or when a line is lightly loaded).
- A 40 mile line to the Golden Plains wind farm was added for Cases 4 and 5.
- The 160 MW wind farm (Cases 4 to 6) is modeled as a generator which controls the voltage at its terminals. Note that the wind farm would employ a switched shunt device which would switch in capacitor banks in discrete steps, but this is currently modeled using a continuous reactive power/voltage controller. This eliminates guess-work in the voltage set-points and bank-sizes of a switched shunt, since the wind farm is at a preliminary stage. The continuous reactive power output of the SVC will approximate the switched shunt behavior.
- The switched shunt capacitor at Bus 70460 (Walsh 69 kV) was modified so its adjustment method is continuous (instead of discrete) to improve convergence qualities for many of the solved cases.
- The power imported/exported into/out of the WECC system is handled by a proportionate reduction/increase of generation in zones 700 and 706.
- During contingency analysis, all tap changers and phase shifters were locked at their base case positions. Switched Var Devices were allowed to operate during contingencies (see discussion on PSLF problems above).

## **Outage List**

Each of the load flow cases listed in Table 1 is first run with all lines in service (the existing base case), but then single contingency outage cases are repeated with all lines (115 kV and above) and all devices shown in Appendix 1 out of service. This includes 13 lines, 5 transformers, 3 shunt reactors and 1 generator connected at these busses, each of which is removed from service.

Appendix 2 shows a table of each of the contingency cases run with the corresponding HVDC power, wind farm power and generation changes in the WECC system. Note the power order reductions specified during contingency 2 (loss of Lamar-Boone 230 line).

The solved load flow for each of the base cases (with all devices in service) resulted in voltages at shunt reactor locations, which were below the set-points of the switched shunt device, so contingency cases 19-21 (which remove the shunt reactors from service) are not required.

Contingency case 18 (removal of 115 kV line from Boone 70060 to LajuntaW 70249) results in an islanded system in the LajuntaW system (i.e., there is no local generation to meet load requirements), so this contingency case is also not performed.

All cases shown in this report were performed with an AC voltage control mode in the HVDC link with 50 MVAR capability, as required in the HVDC specification.

## **Load Flow Case List and Monitoring**

As per the Study Plan, the power transferred through all devices in Zones 704 (I-25 Corridor) and 712 (West Plains – Southern Colorado) are monitored to ensure ratings are not exceeded. The voltages at all busses in Zones 704 and 712 are monitored to ensure they are within specifications ( $0.95 < V_{pu} < 1.05$ ). Finally all the above bus voltages were monitored during contingencies for incremental changes from their base-case values. The WECC criterion specifies the voltage cannot change by more than 5% for any single contingency.

## Study 1) Load Flow Results

A total of 108 load flow cases have been considered: 6 base cases \* 18 cases each (base case plus 17 contingencies). The case list and monitoring is setup using the EPCL scripting facilities in PSLF. The PSLF output of voltages, transformer overloads and transmission line overloads is automatically processed into Excel spreadsheets for each of the 6 base cases and for each contingency case. The programs used for the contingency processing were specifically modified for this study to enable output of incremental voltage deviations (contingency voltages which differ from the base case voltages by more than 5%).

The results are shown in Appendix 3 (Case C - DC link has an AC voltage control mode with +50/-20 MVAR additional reactive power capacity).

### All cases, both before and after the DC link is added, show the following problems:

- Undervoltages at many 115 kV busses (near Lajunta) during contingency 7 (loss of Boone 230/115 transformer) – typical voltages being around 0.91 pu . This transformer's tap control regulates voltages in the 115 system during normal operation, so when it is lost undervoltages occur. The 115 kV system is connected back to the grid through the Lamar 230/115 transformer, but this connection is insufficient to maintain bus voltages.
  - Overloading of the LajuntaW 115/69 transformer occur for most contingencies up to 1.043 pu.
  - Contingency 16 (loss of Boone-Dot Tap 115 kV line) results in an incremental voltage change more than 5% at the DOT, DOT TAP and, for some cases, the APT TAP2 115 kV busses. The absolute voltages are still within tolerance however.
1. The original base case (before the DC or wind farm is added) shows a few problems:
- Minor overvoltages at Lamar 230 bus for contingencies 4 (loss of Lamar 230/115 transformer) and 11 (loss of MidwayPS to MidwayBR 230 line) - worst overvoltage = 1.061 pu. These overvoltages can be solved by tap changer adjustments, as they did not show up as violations in the last report.
2. When 210 MW is imported into the WECC system via the DC (no wind farm), then:
- Note Cases B-2 and C-2 (contingency 2 - loss of Lamar-Boone 230 line) require a power order reduction to 100 MW to avoid overloading the Lamar 230/115 transformer.
  - For Case C-2, contingency 2 (loss of Lamar-Boone 230 line), a slight overload of the Lamar 230/115 transformer occurs (its 100 MVA rating is exceeded by the 100 MW DC power plus the small additional MVAR output for AC voltage control). If the emergency rating of this transformer is not sufficient, then the power order would have to be reduced (below 100 MW) so the DC MW+MVAR output will be less than 100 MVA.
  - For Case C-2, contingency 7 (loss of Boone 230/115 transformer), then the undervoltages in the 115 kV system are slightly improved, but still outside tolerance (despite controlling the Lamar 230 kV bus to 1.04 pu). This shows that the tap changer on the Boone 230/115 transformer is essential to control voltage in the 115 kV system.

3. When 210 MW is exported from the WECC system via the DC (no wind farm), then:
  - Without AC voltage control at the DC link terminals (from Case B in the last report), it was observed;
    - o severe undervoltages occur at the Lamar 230 bus and nearby system for nearly all contingencies.
    - o note Case 5 did not solve (indicating severe undervoltages/overloads).
  - With AC voltage control at the DC link terminals (Case C), then most problems are solved, except for:
    - Minor undervoltages (approx .94 pu) during contingency 5 (loss of Boone-Comanche 230 line).
      - If tap changers are allowed to operated (from the last report), the undervoltages occur at Boone and Lamar 230 busses. A slightly higher DC link MVAR rating (52 MVAR) would raise the Lamar voltage to 0.95, but 64 MVARs would be required for the Boone voltage.
      - If tap changers are locked:
        - o The undervoltages occur at LajuntaT and LajuntaW 115 kV busses (0.944 and 0.909 pu).
        - o A detailed printout of the power flow and voltages at all critical busses for this case is shown in Appendix 4. Note the DC link is exporting a full 210 MW and is generating 50 MVAR into the system.
      - The incremental voltages also change by more than 5% (for contingency 5) at 8 busses between Boone and Lamar (typical around 6-7%) when taps are not allowed to operate.
    - Note: A DC power order reduction to 48 MW was required during contingency 2 (loss of Lamar-Boone 230 kV line) to maintain voltages and loadings within tolerance (based on a separate sensitivity study to determine the level of DC power order reduction necessary for adequate system operation).
4. This base case is similar to Case 2 above in that a total of 210 MW is injected into the WECC system except now 160 MW comes from the wind farm and 50 from the DC. The results are nearly identical to item 2 above. Note for contingency 2 (loss of Lamar-Boone 230 line) requires the power order to change from an import of 50 MW to an export of 60 MW so as to not overload the Lamar 230/115 transformer.
5. This case has the wind farm operating at full capacity (160 MW) and a full export of 210 MW on the DC, resulting in a net draw of 50 MW from the WECC system.
  - If AC voltage control is not added at the DC link terminals (Case B from the last report), then
    - o undervoltages occur at the Lamar 230 bus and nearby system for contingency 2 (loss of Lamar-Boone 230 line). It is anticipated that a further power order reduction could be performed, which would bring bus voltages within tolerance.
  - If AC voltage control is added at the DC link terminals (Case C):
    - o The system operates within tolerance for nearly all contingencies without a power order reduction.

- A minor overvoltage (1.052 pu) occurs at Vilas 115 during contingency 15 (loss of Lamar-Wilow CK 115 line) when tap changers are allowed to operate (from the last report). This is due to the Ferranti effect (a lightly loaded line will have a higher voltage at its endpoint) and is easily solved if the set-point of the AC voltage control mode of the DC link is reduced slightly from its current set-point of 1.04 pu.
  - A slight undervoltage (.937 pu) occurs at LajuntaT for contingency 2 (loss of the Lamar-Boone 230 line) if the taps are locked (this report), but is resolved with a tap changer operation of the Boone 230/115 transformer (from the last report). The voltage also changes by 8% at this bus during this contingency.
  - The Boone 230/115 transformer was slightly overloaded (.6%) during contingency 2 (loss of Lamar-Boone 230 line) if the tap changers are allowed to operate (from the last report). When the taps are locked (Case 5 in this report), the load reduces to 0.992 pu.
6. This case has the wind farm operating at full capacity (160 MW) in addition to a full import of 210 MW on the DC, resulting in a net import of 370 MW into the WECC system.
- Note Case C-2 (contingency 2 - loss of Lamar-Boone 230 line) requires a power order reversal to -60 MW to avoid overloading the Lamar 230/115 transformer.
  - A slight undervoltage (.937 pu) occurs at LajuntaW for contingency 5 (loss of the Boone-Comanche 230 line). This likely could be solved by a tap changer operation of the Boone 230/115 transformer.
  - The 115 kV transmission line from PUEB-TAP(70336) to W.STATON(70456) was slightly overloaded (1.048 pu) during contingency 9 (loss of the Comanche-Walsenbg 230 kV line).



## Study 1) Load Flow Discussion and Summary

The new study results do not significantly change the conclusions presented in the earlier report. The specific changes in this study compared to the last study are:

- The loss of a single Comanche generator does not result in any difficulties for any of the cases studied.
- The full import of 210 MW HVDC plus 160 MW wind farm (for a total of 370 MW into the WECC system) does not introduce any new significant difficulties:
  - A minor undervoltage (.937 pu) at the Lajunta W 115 kV bus occurs during Contingency 5 (loss of the Boone-Comanche 230 kV line), which does not occur for a total import of 210 MW (Case 2). This could likely be solved by a tap changer operation of the Boone 230/115 transformer.
  - A minor transmission line overload (1.048 pu) on the PUEB-TAP to W.STATON 115 kV line during Contingency 9 (loss of the Comanche-Walsenbg 230 kV line).
- The locking of tap changer settings during contingencies has a small but not dominant effect on the conclusions.
- The monitoring of incremental bus voltage deviations identify largely the same contingencies as for the monitoring of the absolute voltages. The only exceptions are:
  - All Cases – Contingency 16 (loss of Boone-Dot Tap 115 kV line) results in an incremental voltage change more than 5% at the DOT, DOT TAP and APT TAP2 115 kV busses (the absolute voltage are within tolerance).
  - Base Case 3 (210 MW Export) – Contingency 5 (loss of Boone-Comanche 230 kV line) results in numerous incremental voltage changes of more than 5% near Boone, Lamar, Lajunta and DOT.

Problems during all cases analyzed (including the pre-existing system) are evident:

- Contingency 5 (the loss of the Boone 230/115 transformer). The loss of this tap-changer results in very low undervoltages throughout the 115 kV system near Lajunta, APT and DOT.
- Minor overloading of the LajuntaW 115/69 kV transformer (around 5% overload), for all contingencies and even in steady state with all devices in service.
- Contingency 16 (loss of Boone-Dot Tap 115 kV line) results in an incremental voltage change more than 5% at the DOT, DOT TAP and, for some cases, the APT TAP2 115 kV busses. The absolute voltages are still within tolerance however.

The dominant critical contingency cases are:

1. Loss of the Lamar-Boone 230 kV line (contingency 2).  
This case necessitates a power order reduction in order to avoid overloading the Lamar 230/115 transformer). The power order reductions required are:
  - Case 2 (Importing 210 MW from DC) – reduction to importing of 100 MW from DC.

- Case 3 (Exporting 210 MW to DC) – reduction to exporting of 48 MW to DC (only possible if combined with AC voltage control mode of the DC link).
- Case 4 (Importing 50 from DC + 160 MW from wind) – reversal to exporting of 60 MW to DC.
- Case 5 (Exporting 210 to DC + 160 from wind) – no reduction required.
- Case 6 (Importing 210 from DC + 160 MW from wind) – reversal to exporting of 60 MW to DC.

These levels of power order reductions (100 MW and 48 MW) are based on steady state load flow studies and cannot necessarily be applied in the final system without a detailed PSCAD transients study. The very low short circuit ratio when the Lamar Boone line trips can be challenging for HVDC system operation and the dynamic operation will likely determine the power order reduction levels (not the steady state criteria).

2. Loss of the Boone 230/115 kV transformer (contingency 7).  
In all cases (including the base case before the DC system is added) this resulted in extensive undervoltages in the 115 kV system near Lajunta. The additional power imported from the DC link helps the situation (via the 115 system connection at Lamar), but is not sufficient to prevent the undervoltages (even with the AC voltage control mode of the DC link).
3. Loss of the Boone-Comanche 230 Line during the exporting of 210 MW (Base Case 3, contingency 5).

Previous study results (Task 8) reported that the addition of an AC voltage control mode to the DC Link could hold the Lamar 230 bus close to tolerances (.948 pu and the Boone 230 Bus at .941 pu.) (Task 8 studies allowed the tap changers, phase shifters and SVD devices to operate). Subsequent studies showed 52 MVAR capacity instead of 50 MVAR (in addition to the 105 MVARs of AC filters) was sufficient to bring the Lamar 230 volts to .95 pu, but 64 MVARs would be required to bring the Boone 230 volts to .95 pu.

The study results shown in this report (with tap changers and phase shifters fixed during contingencies, with 50 MVAR of reactive power available for the ac voltage control of the DC link) showed the absolute voltages at Lamar 230 and at Boone 230 are now within tolerance, but there are undervoltages at LajuntaT and LajuntaW 115 kV busses (of 0.944 and .909 pu) . The incremental voltages also change by more than 5% at 8 busses between Boone and Lamar (typical around 6-7%).

4. For nearly all cases (including the base case before the DC link is added), contingency 16 (loss of Boone-Dot Tap 115 kV line) results in an incremental voltage change more than 5% at the DOT, DOT TAP and APT TAP2 115 kV busses. The absolute voltages are still within tolerance however.

The benefit of adding an AC voltage control mode to the DC link is most evident when exporting power out of the WECC system.

- Without the AC voltage control mode of the DC link (refer to Case 3B in the April 2002 report), severe undervoltages exist near Lamar 230 for nearly all contingencies.
- With +50/-20 MVAR reactive power limits in the AC voltage control mode of the DC link (refer to Case 3C) then operation is successful and mostly within tolerances.

## **2) Stability Studies**

Stability studies were performed as part of Task 8 (see Final Report – April 19, 2002) to ensure electro-mechanical oscillations were damped during large disturbances of the HVDC system and that voltages were within WECC criteria. These results from the Task 8 report have been included in this report, with additional plots of the angles at the Comanche and Nixon generators included.

PSLF stability data has been provided by XCEL Energy for this study (Case 05ha1sa.sav and 05ha1s1.dyd, received November 27, 2001).

The impact of the Golden Plains wind farm and possible interactions with the HVDC system were not analyzed in this stage of the studies. Study 2) above indicated that the wind farm project was in a preliminary state and that a suitable design and interconnection specification was not finalized. The high degree of uncertainty in the design and specification would introduce too many variables and options to study the combined operation of the wind farm and HVDC system in sufficient detail.

The HVDC system was represented as a simple PQ load in the stability program due to limitations and complexities in stability HVDC models while operating under very low Short Circuit Ratios (as occurs when the Lamar – Boone 230 line is tripped). The PQ load values were stepped to lower levels to represent an HVDC power order reduction, as required. This representation is considered valid because the worst case and the largest step disturbance (for the study the stability of electro-mechanical oscillations) occurs when the DC system is tripped out. For the study of ac voltage transients and interactions with nearby machines, the HVDC system was represented in detail in Study 3) below.

The closest machine to the Lamar system is a small 25 MW machine connected near the Willow Creek 115 bus (at CTY LAM). The possibility of a mechanical oscillation of this machine against the system past Boone (initiated by a disturbance near Lamar) was investigated.

The base cases investigated using the transient stability program were:

- 1) Original Base Case (before HVDC System was added)
- 2) DC System at full import capability (210 MW)
- 3) DC System at full export capability (-210 MW)

Disturbances investigated were:

- o Case 1a (import and export) - Emergency Block of HVDC system without tripping of filters
- o Case 1b (import and export) - Emergency Block of HVDC system and tripping of filters

- Case 2 (import and export) - Fault on Lamar-Boone 230 line, trip and HVDC power order reduction
- Case 3 (import and export) - Faults on Lamar-Willow Creek 115 line, trip
- Case 4 (import and export) - Faults on LajuntaT-Willow Creek 115 line, trip

### **Stability – Acceptance Criteria**

The document entitled “NERC/WECC Planning Standards” specifies allowable criteria and limits that must be met before new equipment can be added to the system. This portion of study considers stability criteria for N-1 single contingencies.

For each of the base cases, each contingency will be considered and specified bus voltages will be monitored to ensure they are within specifications. The voltage criterion specifies the time duration of voltage dips not to exceed 20% for 20 cycles. In addition, electro-mechanical oscillations must be damped over the ten (10) second duration of each simulation (reference Table W-1 and Figure W-1, pages 12-13 of NERC/WECC Planning Standards).

In addition, TOV voltage specifications from the HVDC specifications (Figure 8.1 on Page 48) in the document entitled “Xcel Energy Services, Inc., Request for Proposal LB1003, 210 Megawatt Back-to-Back Dc Converter at Lamar, Co.” (dated April 5, 2002) were followed. These provide for maximum allowable voltages as a function of time.

- TOV values must be controlled to no more than 1.3 times the max continuous operating voltage within 50 msec.
- TOV values must be controlled to no more than 1.2 times the max continuous operating voltage within 200 msec.
- TOV values must be controlled to within 1% of normal operation voltage within 2 sec.

### **Study 2) Transient Stability Results**

Appendix 5.1-5.3 contains PSLF simulation traces for each of the above cases. The cases were run for ten seconds (as per the WECC planning guide) to ensure all oscillations were damped within this period.

- Appendix 5.1 – Original Base Case (without DC)
- Appendix 5.2 – Importing 210 MW
- Appendix 5.3 – Exporting 210 MW

For each case run, time domain graphs of the following quantities are shown:

- Plot 1 - 230 kV voltages near Lamar and Boone
- Plot 2 - 115 kV voltages near Lamar and Boone
- Plot 5 - CTY LAM, Comanche and Nixon machine angles

In addition to the plots shown, real and reactive power through the transmission lines and transformers were monitored to ensure they are within ratings for the single contingencies studied (the final PQ levels were verified from loadflow studies performed in Study 1) above).

Electro-mechanical oscillations were damped for all cases.

Notes for Base Case 1 - Pre-existing system before the DC system was added:

- Case 3 (fault on Lamar-Willow Creek 115 kV line and trip) resulted in post-disturbance voltages above 1.05 pu at the Lamar 230 and 115 busses.

The load flow studies in Study 1 above did not show an overvoltage for this contingency. The difference between the load flow and transient stability results is that tap changers and switched shunt devices are not operational during transient stability simulations. Therefore the overvoltages following this disturbance can only be reduced by operation of tap-changers or the switching of a reactor bank.

Notes Common to Base Cases 2 and 3 - HVDC Importing and Exporting 210 MW:

- Voltages for Case 1a (block of DC without tripping filters) are above specification.
- Voltages for Case 1b (block of DC with tripping of filters) are within tolerance, indicating that HVDC AC filters must be tripped after the DC is blocked.
- Damped oscillations are evident in the voltages near Lamar when the Lamar-Boone 230 kV line is tripped (Case 2i). The oscillations are at 2.5 Hz and are primarily due to the CTY LAM machine (in the 115 kV system near Willow Creek).
- Cases 2i and 2e (fault on Lamar-Boone 230 kV line and trip) show dynamic voltage swings that are damped, but are above the TOV 2 second limit. The oscillations are at 2.5 Hz and are primarily due to the CTY LAM machine (near the 115 kV system at Willow Creek) and its response to a stepped PQ load change (this is how the HVDC power order reduction is performed in the stability program). More detailed studies were performed to study this using the PSCAD program (see Studies in 4 below). The PSCAD results (with the HVDC system now represented in detail) show the oscillation with a higher degree of damping and show the voltages to be within the TOV limits.

Notes for Base Case 2 – HVDC System Importing 210 MW:

- Case 3i (fault on Lamar-Willow Creek 115 kV line and trip) shows steady state voltages higher than 1.05. This is due to the representation of the DC system as a constant PQ load in the stability program. In this simple representation, the DC system continues to operate at the same PQ levels even after the line trips. In a more detailed model, the AC voltage control mode of the HVDC system would have reduced the voltage back down to the pre-fault levels (this was not represented in the stability program but is represented in the detailed PSCAD models in Studies 4 below).

The representation of the HVDC system as a simple PQ load is valid when studying electro-mechanical oscillations and machine swings/stability (particularly since the worst case disturbance occurs when the HVDC system is suddenly blocked), but will not properly represent the dynamic voltage regulation in the Lamar system and is thus not suitable to look at HVDC interactions with nearby machines. To study these aspects, additional studies were performed using a generic but detailed HVDC system model in the PSCAD model, as reported in Study 4) below.

### **3) HVDC Electro-magnetic Transients Studies**

The following results are copied directly from the Task 8 Final Report (April 19, 2002).

PSCAD studies were performed to represent the HVDC system in more detail and look for possible voltage stability problems and electro-mechanical oscillations against the CTY LAM machine. The concern was that the Lamar system has a very low Short Circuit Ratio (particularly when the Lamar-Boone line is tripped) and that the transient

stability representation of HVDC systems would not be accurate or even feasible. For this reason, the HVDC system and controls were represented in detail, as was the 25 MW generator/ST3A exciter/gas turbine at the CTY LAM bus (which feeds into the Willow Creek 115 kV system).

The PSCAD system diagram for the circuit and generic HVDC controls used in this study is shown in Appendix 6. The model used in the specification studies was used as a starting point. The system includes detailed line models of the 230 and 115 kV system in the circuits between Lamar and Boone, with loads and system equivalents as per the model used as per the specification model. Note that the system represented in this study will have a higher Short Circuit Ratio than that used in the specification (which was a worst case model), due mainly to the addition of the CTY LAM 25 MW machine.

The cases from Study 3 above were repeated (except now on PSCAD instead of a transient stability program). Results are shown in Appendix 7, with plots of AC 230 Volts, AC 115 Volts, CTY LAM machine angle and HVDC quantities.

Disturbances investigated were:

- Case 1a (import and export) - Emergency Block of HVDC system without tripping of filters
- Case 1b (import and export) - Emergency Block of HVDC system and tripping of filters
- Case 2 (import and export) - Fault on Lamar-Boone 230 line, line trip and HVDC power order reduction
- Case 3 (import and export) - Fault on Lamar-Willow Creek 115 line, trip
- Case 4 (import and export) - Fault on LajuntaT-Willow Creek 115 line, trip

### **Study 3) Electro-magnetic Transients Study Results:**

- All electro-mechanical oscillations in the studies performed were damped (using generic HVDC controls).
- The HVDC system showed an interaction with the 25 MW machine at CTY LAM. Early studies performed with a faster master power controller resulted in 2.5 Hz oscillations that were critically damped. In the studies shown in this report (using generic HVDC controls), a slow dc voltage signal into the Master Power Controller was sufficient to ensure oscillations against the 25 MW machine were damped.
- Once the final HVDC control design is complete, a detailed study of the interactions between the HVDC system and nearby machines should be performed to see if a PSS damping controller is required (a provision for a PSS input is in the HVDC specification).
- The AC filters of the HVDC link must be tripped after a blocking operation (or power order reduction) to prevent long-duration overvoltages and overloading of the CTY LAM machine.
- All voltages are within WECC undervoltage criteria and meet the TOV criteria in the HVDC specification (as long as AC filters are tripped during blocking of the HVDC system or during power order reductions).

## **Task 8 Addendum Conclusions**


- 1) HVDC Power Order reductions must be performed if the Lamar-Boone 230 kV line is tripped (this is provided for in the HVDC specification). The final levels of power transfer during this contingency will depend largely on the dynamic performance of the HVDC scheme selected while operating under very low short circuit ratios.
- 2) The AC filters of the HVDC system must be tripped if the DC link is blocked (this is provided for in the HVDC specification).
- 3) If an AC voltage control mode is added at the DC link, then full power can be imported or exported through all single contingencies (additional reactive power capability and an AC voltage control mode is provided for in the HVDC specification).
- 4) The HVDC system showed an interaction with the 25 MW machine at CTY LAM, however the interactions were damped (using preliminary HVDC control models).
- 5) Once the final HVDC control design is complete, a detailed study of the interactions between the HVDC system and nearby machines should be performed to see if a PSS damping controller is required (a provision for a PSS input is provided for in the HVDC specification).
- 6) The pre-existing system (before the HVDC system is added) can result in undervoltages in the 115 kV system near Lajunta if the Boone 230/115 transformer is lost. The addition of the HVDC system slightly improves the situation, by providing reactive power through the 115 kV system from Lamar, but does not prevent the undervoltages for this contingency.
- 7) The system during contingency 16 (loss of the Boone-Dot 115 line) will result in incremental voltages at the Dot 115 bus, which differ from the steady state values by more than 5% (both before and after the HVDC system is added).
- 8) The loss of the Comanche - Boone 230 kV Line while the WECC Colorado system was exporting 210 MW to SPP created a 5% voltage deviation for busses between Boone and Lamar and undervoltages around 0.94 pu on the La Junta 115 kV buses.

The addition of the Lamar HVDC Back to Back system (as per the design in the HVDC specification) will not have any adverse reactions on the WECC system as long as operating procedures are followed for certain contingencies and AC voltage control is used for the DC link.

## **Acknowledgements**

This study was prepared by the Electranix Corporation and the Manitoba HVDC Research Centre. Contributions to this study were made by Dr. Alan Wang (Manitoba HVDC Research Centre), Alfred Lee and Saif Imran (Teshmont Consultants).

Special acknowledgement and thanks to James Whitaker (Xcel Energy) for his system expertise and guidance in these studies.



## Appendix 1 - Load Flow Bus Specification



Case #	Outage	Bus #'s	1) Original			2) Import 210 MW			3) Export 210 MW			4) Import 50 + 160 Wind			5) Export 210 + 160 Wind			6) Import 210 + 160 Wind		
			DC	Wind	Δ Gen	DC	Wind	Δ Gen	DC	Wind	Δ Gen	DC	Wind	Δ Gen	DC	Wind	Δ Gen	DC	Wind	Δ Gen
1	All Lines and Transformers In Service		0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
2	230 Line	70254-70061	0	0	0	100*	0	-210	-48*	0	210	-60*	160	-210	-210	160	50	-60*	160	-370
3	230 Line	70254-70560	0	0	0	0#	0	-210	0#	0	210	0#	160	-210	0#	160	50	0#	160	-370
4	230/115 Transf	70254-70253	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
5	230 Line	70061-70122	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
6	230 Line	70061-70286	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
7	230/115 Transf	70061-70060	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
8	230 Line	70122-70286	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
9	230 Line	70122-70459	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
10	230/115 Transf	70122-70121	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
11	230 Line	70286-73413	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
12	230/115 Transf	70286-70285	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
13	115 Line	70247-70472	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
14	115 Line	70253-70452	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
15	115 Line	70253-70472	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
16	115 Line	70060-70159	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
17	115 Line	70060-70247	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
18	115 Line	70060-70249	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
19	115 Shunt React	70285	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
20	115 Shunt React	70253	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
21	115 Shunt React	70060	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370
22	Comanche Generator	70121	0	0	0	210	0	-210	-210	0	210	50	160	-210	-210	160	50	210	160	-370

## Appendix 2 - Case Descriptions - DC, Wind Farm and Change in WECC Generation (MW)

Notes: - \* indicates a dc power order reduction or reversal

- # indicates a dc shutdown due to loss of connector line from LAMAR DC to LAMAR CO 230 bus

**Appendix 3 – Load Flow Study Results  
(+50/-20 MVAR AC Voltage Control Capability of HVDC Link)**

## Multi-case Voltage Summary

### Base Case 05ha1sa-1b - Original Load Flow

Zones for the criteria check are:

704,712

Minimum bus voltage level 115.0 kV

Minimum voltage filter = 0.95 p.u.

Maximum voltage filter = 1.05 p.u.

Based on N-1 contingency power flow criteria

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	1b_LF01	Base Case (all in service)	2	1b_LF02	Lamar Co 70254-Boone 70061 230 Line
3	1b_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	1b_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	1b_LF05	Boone 70061-Comanche 70122 230 Line	6	1b_LF06	Boone 70061-Midwayps 70286 230 Line
7	1b_LF07	Boone 70061-Boone 70060 230/115 Transf	8	1b_LF08	Comanche 70122-Midwayps 70286 230 Line
9	1b_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	1b_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	1b_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	1b_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	1b_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	1b_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	1b_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	1b_LF16	Boone 70060-Dot Tap 70159 115 Line
17	1b_LF17	Boone 70060-Lajuntat 70247 115 Line	18	1b_LF22	Comanche generator #1 70119

Bus				min volts	max volts	Cases where voltage is outside criteria																		Violation count	Actual	
bus	name	kV	zone			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		min volts	max volts
70094	CF&IFURN	230.0	704	0.95	1.05																		0	1.050	1.050	
70122	COMANCHE	230.0	704	0.95	1.05										x								1	1.052	1.052	
70549	APT MEM	115.0	712	0.95	1.05						x												1	0.926	0.926	
70030	APT PARK	115.0	712	0.95	1.05						x												1	0.929	0.929	
70031	APT TAP	115.0	712	0.95	1.05						x												1	0.935	0.935	
70022	APT TAP2	115.0	712	0.95	1.05						x												1	0.923	0.923	
70060	BOONE	115.0	712	0.95	1.05						x												1	0.906	0.906	
70158	DOT	115.0	712	0.95	1.05						x												1	0.907	0.907	
70159	DOT TAP	115.0	712	0.95	1.05						x												1	0.909	0.909	
70247	LAJUNTAT	115.0	712	0.95	1.05						x												1	0.937	0.937	
70249	LAJUNTAW	115.0	712	0.95	1.05					x	x												2	0.844	0.945	
70254	LAMAR CO	230.0	712	0.95	1.05				x						x								2	1.052	1.061	

Identifies the actual minimum voltage.

Identifies the actual maximum voltage.

x denotes a violation; f flags voltages outside of the range.

## Multi-Case Delta Voltage Summary

### Base Case 05ha1sa-1b - Original Load Flow

Zones for the criteria check are:

704,712

minimum voltage level 115.0 kV

Based on N-1 contingency power flow criteria

dv = 0.05 p.u.

Case no	Case Id	Case Description	Case no	Case Id	Case Description
	1 1b_LF01	Base Case (all in service)		2 1b_LF02	Lamar Co 70254-Boone 70061 230 Line
	3 1b_LF03	Lamar Co 70254-Lamar 70560 230 Line		4 1b_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 1b_LF05	Boone 70061-Comanche 70122 230 Line		6 1b_LF06	Boone 70061-Midwayps 70286 230 Line
	7 1b_LF07	Boone 70061-Boone 70060 230/115 Transf		8 1b_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 1b_LF09	Comanche 70122-Walsenbg 70459 230 Line		10 1b_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 1b_LF11	Midwayps 70286-Midwaybr 73413 230 Line		12 1b_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 1b_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line		14 1b_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 1b_LF15	Lamar co 70253-Wilow Ck 70472 115 Line		16 1b_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 1b_LF17	Boone 70060-Lajuntat 70247 115 Line		18 1b_LF22	Comanche Generator #1 70119

number	Bus name	kV	zone	Cases that exceeded dv limit																		Violation count	max dv
				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70022	APT TAP2	115.0	712							X												1	0.082
70030	APT PARK	115.0	712							X												1	0.073
70031	APT TAP	115.0	712							X												1	0.067
70549	APT MEM	115.0	712							X												1	0.077
70060	BOONE	115.0	712							X												1	0.114
70158	DOT	115.0	712							X									X			2	0.108
70159	DOT TAP	115.0	712							X									X			2	0.107
70247	LAJUNTAT	115.0	712							X												1	0.076
70249	LAJUNTAW	115.0	712							X												1	0.121
70301	NTHRIDGE	115.0	712							X												1	0.051

x denotes dv over 0.05 p.u.

### Transformer Multi-case Overload Summary

#### Base Case 05ha1sa-1b - Original Load Flow

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
	1 1b_LF01	Base Case (all in service)		2 1b_LF02	Lamar Co 70254-Boone 70061 230 Line
	3 1b_LF03	Lamar Co 70254-Lamar 70560 230 Line		4 1b_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 1b_LF05	Boone 70061-Comanche 70122 230 Line		6 1b_LF06	Boone 70061-Midwayps 70286 230 Line
	7 1b_LF07	Boone 70061-Boone 70060 230/115 Transf		8 1b_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 1b_LF09	Comanche 70122-Walsenbg 70459 230 Line		10 1b_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 1b_LF11	Midwayps 70286-Midwaybr 73413 230 Line		12 1b_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 1b_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line		14 1b_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 1b_LF15	Lamar co 70253-Wilow Ck 70472 115 Line		16 1b_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 1b_LF17	Boone 70060-Lajuntat 70247 115 Line		18 1b_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct		Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70250	LAJUNTAW	69.0	712	70249	LAJUNTAW	115.0	712	1		25.0 M																			18	1.039

Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

### Transmission Line Multi-case Overload Summary

#### Base Case 05ha1sa-1b - Original Load Flow

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	1b_LF01	Base Case (all in service)	2	1b_LF02	Lamar Co 70254-Boone 70061 230 Line
3	1b_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	1b_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	1b_LF05	Boone 70061-Comanche 70122 230 Line	6	1b_LF06	Boone 70061-Midwayps 70286 230 Line
7	1b_LF07	Boone 70061-Boone 70060 230/115 Transf	8	1b_LF08	Comanche 70122-Midwayps 70286 230 Line
9	1b_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	1b_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	1b_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	1b_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	1b_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	1b_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	1b_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	1b_LF16	Boone 70060-Dot Tap 70159 115 Line
17	1b_LF17	Boone 70060-Lajuntat 70247 115 Line	18	1b_LF22	Comanche Generator #1 70119

no transmission lines in the selected area(s) and with the selected voltage level(s) have overloads greater than the criteria

## Multi-case Voltage Summary

**Base Case 05ha1sa-2c - DC Power = 210 MW(Import), dc bus at 1.04 p.u.**

**Zones for the criteria check are:**

**704,712**

**Minimum bus voltage level 115.0 kV**

**Minimum voltage filter = 0.95 p.u.**

**Maximum voltage filter = 1.05 p.u.**

**Based on N-1 contingency power flow criteria**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
	1 2c_LF01	Base Case (all in service)		2 2c_LF02a	Lamar Co 70254-Boone 70061 230 Line - PDC 100 MW
	3 2c_LF03	Lamar Co 70254-Lamar 70560 230 Line		4 2c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 2c_LF05	Boone 70061-Comanche 70122 230 Line		6 2c_LF06	Boone 70061-Midwayps 70286 230 Line
	7 2c_LF07	Boone 70061-Boone 70060 230/115 Transf		8 2c_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 2c_LF09	Comanche 70122-Walsenbg 70459 230 Line		10 2c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 2c_LF11	Midwayps 70286-Midwaybr 73413 230 Line		12 2c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 2c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line		14 2c_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 2c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line		16 2c_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 2c_LF17	Boone 70060-Lajuntat 70247 115 Line		18 2c_LF22	Comanche Generator #1 70119

bus	Bus name	kV	zone	min volts	max volts	Cases where voltage is outside criteria																		Violation count	Actual	
						1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		min volts	max volts
70549	APT MEM	115.0	712	0.95	1.05							x												1	0.926	0.926
70030	APT PARK	115.0	712	0.95	1.05							x												1	0.929	0.929
70031	APT TAP	115.0	712	0.95	1.05							x												1	0.935	0.935
70022	APT TAP2	115.0	712	0.95	1.05							x												1	0.923	0.923
70060	BOONE	115.0	712	0.95	1.05							x												1	0.905	0.905
70158	DOT	115.0	712	0.95	1.05							x												1	0.906	0.906
70159	DOT TAP	115.0	712	0.95	1.05							x												1	0.909	0.909
70247	LAJUNTAT	115.0	712	0.95	1.05							x												1	0.928	0.928
70249	LAJUNTAW	115.0	712	0.95	1.05							x												1	0.844	0.844
70301	NTHRIDGE	115.0	712	0.95	1.05							x												1	0.950	0.950

Identifies the actual minimum voltage.

Identifies the actual maximum voltage.

x denotes a violation; f flags voltages outside of the range.

## Multi-Case Delta Voltage Summary

Base Case 05ha1sa-2c - DC Power = 210 MW(Import), dc bus at 1.04 p.u.

Zones for the criteria check are:  
704,712

dv = 0.05

Case no	Case Id	Case Description	Case no	Case Id	Case Description
	1 2c_LF01	Base Case (all in service)		2 2c_LF02a	Lamar Co 70254-Boone 70061 230 Line - PDC 100 MW
	3 2c_LF03	Lamar Co 70254-Lamar 70560 230 Line		4 2c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 2c_LF05	Boone 70061-Comanche 70122 230 Line		6 2c_LF06	Boone 70061-Midwayps 70286 230 Line
	7 2c_LF07	Boone 70061-Boone 70060 230/115 Transf		8 2c_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 2c_LF09	Comanche 70122-Walsenbg 70459 230 Line		10 2c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 2c_LF11	Midwayps 70286-Midwaybr 73413 230 Line		12 2c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 2c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line		14 2c_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 2c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line		16 2c_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 2c_LF17	Boone 70060-Lajuntat 70247 115 Line		18 2c_LF22	Comanche Generator #1 70119

Bus				Cases that exceeded dv limit																		Violation	
number	name	kv	zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	count	max dv
70022	APT TAP2	115.0	712							X												1	0.083
70030	APT PARK	115.0	712							X												1	0.073
70031	APT TAP	115.0	712							X												1	0.067
70549	APT MEM	115.0	712							X												1	0.078
70060	BOONE	115.0	712							X												1	0.118
70158	DOT	115.0	712							X									X			2	0.111
70159	DOT TAP	115.0	712							X									X			2	0.111
70247	LAJUNTAT	115.0	712							X												1	0.083
70249	LAJUNTAW	115.0	712							X												1	0.126
70301	NTHRIDGE	115.0	712							X												1	0.050

x denotes dv over 0.05 p.u.



### Transformer Multi-case Overload Summary

Base Case 05ha1sa-2c - DC Power = 210 MW(Import), dc bus voltage at 1.04 p.u.

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	2c_LF01	Base Case (all in service)	2	2c_LF02a	Lamar Co 70254-Boone 70061 230 Line - PDC 100 MW
3	2c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	2c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	2c_LF05	Boone 70061-Comanche 70122 230 Line	6	2c_LF06	Boone 70061-Midwayps 70286 230 Line
7	2c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	2c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	2c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	2c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	2c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	2c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	2c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	2c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	2c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	2c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	2c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	2c_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct		Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70250	LAJUNTAW	69.0	712	70249	LAJUNTAW	115.0	712	1		25.0 M																	18	1.029		
70253	LAMAR CO	115.0	712	70254	LAMAR CO	230.0	712	1		100.0 M																	1	1.008		

Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

### Transmission Line Multi-case Overload Summary

Base Case 05ha1sa-2c - DC Power = 210 MW(Import), dc bus voltage at 1.04 p.u.

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	2c_LF01	Base Case (all in service)	2	2c_LF02a	Lamar Co 70254-Boone 70061 230 Line - PDC 100 MW
3	2c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	2c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	2c_LF05	Boone 70061-Comanche 70122 230 Line	6	2c_LF06	Boone 70061-Midwayps 70286 230 Line
7	2c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	2c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	2c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	2c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	2c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	2c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	2c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	2c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	2c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	2c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	2c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	2c_LF22	Comanche Generator #1 70119

no transmission lines in the selected area(s) and with the selected voltage level(s) have overloads greater than the criteria

## Multi-case Voltage Summary

**Base Case 05ha1sa-3c - DC Power = -210 MW(Export), dc bus voltage at 1.022 p.u.**

Zones for the criteria check are:

704,712

Minimum bus voltage level 115.0 kV

Minimum voltage filter = 0.95 p.u.

Maximum voltage filter = 1.05 p.u.

Based on N-1 contingency power flow criteria

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	3c_LF01	Base Case (all in service)	2	3c_LF02_bx	Lamar Co 70254-Boone 70061 230 Line - PDC= -48 MW
3	3c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	3c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	3c_LF05	Boone 70061-Comanche 70122 230 Line	6	3c_LF06	Boone 70061-Midwayps 70286 230 Line
7	3c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	3c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	3c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	3c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	3c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	3c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	3c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	3c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	3c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	3c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	3c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	3c_LF22	Comanche Generator #1 70119

bus	Bus name	kV	zone	min volts	max volts	Cases where voltage is outside criteria																		Violation count	Actual	
						1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		min volts	max volts
70549	APT MEM	115.0	712	0.95	1.05							x												1	0.894	0.894
70030	APT PARK	115.0	712	0.95	1.05							x												1	0.898	0.898
70031	APT TAP	115.0	712	0.95	1.05							x												1	0.906	0.906
70022	APT TAP2	115.0	712	0.95	1.05							x												1	0.890	0.890
70060	BOONE	115.0	712	0.95	1.05							x												1	0.866	0.866
70158	DOT	115.0	712	0.95	1.05							x												1	0.868	0.868
70159	DOT TAP	115.0	712	0.95	1.05							x												1	0.871	0.871
70247	LAJUNTAT	115.0	712	0.95	1.05					x		x												2	0.899	0.944
70249	LAJUNTAW	115.0	712	0.95	1.05					x		x												2	0.802	0.909
70301	NTHRIDGE	115.0	712	0.95	1.05							x												1	0.927	0.927

Identifies the actual minimum voltage.

Identifies the actual maximum voltage.

x denotes a violation; f flags voltages outside of the range.

## Multi-Case Delta Voltage Summary

**Base Case 05ha1sa-3c - DC Power = -210 MW(Export), dc bus voltage at 1.022 p.u.**

**Zones for the criteria check are:**

**704,712**

**dv = 0.05**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	5c_LF01	Base Case (all in service)	2	5c_LF02_bx	Lamar Co 70254-Boone 70061 230 Line - PDC=-48 MW
3	5c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	5c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	5c_LF05	Boone 70061-Comanche 70122 230 Line	6	5c_LF06	Boone 70061-Midwayps 70286 230 Line
7	5c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	5c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	5c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	5c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	5c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	5c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	5c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	5c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	5c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	5c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	5c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	5c_LF22	Comanche Generator #1 70119

Bus				Cases that exceeded dv limit																		Violation count	max dv
number	name	kv	zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70022	APT TAP2	115.0	712							X									X			2	0.120
70030	APT PARK	115.0	712							X												1	0.108
70031	APT TAP	115.0	712							X												1	0.099
70549	APT MEM	115.0	712							X												1	0.114
70060	BOONE	115.0	712					X		X												2	0.162
70061	BOONE	230.0	712					X														1	0.063
70158	DOT	115.0	712					X		X									X			3	0.154
70159	DOT TAP	115.0	712					X		X									X			3	0.154
70247	LAJUNTAT	115.0	712					X		X												2	0.102
70249	LAJUNTAW	115.0	712					X		X												2	0.174
70254	LAMAR CO	230.0	712					X														1	0.056
70560	LAMAR DC	230.0	712					X														1	0.056
70301	NTHRIDGE	115.0	712							X												1	0.077

x denotes dv over 0.05 p.u.

### Transformer Multi-case Overload Summary

**Base Case 05ha1sa-3c - DC Power = -210 MW(Export), dc bus voltage at 1.022 p.u.**

**Zones for the criteria check are:**

**704,712**

**Branch rating level for overload assesment = 0**

**Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.**

**Minimum bus voltage level 115.0 kV**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	2c_LF01	Base Case (all in service)	2	3c_LF02_bx	Lamar Co 70254-Boone 70061 230 Line - PDC=-48 MW
3	2c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	2c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	2c_LF05	Boone 70061-Comanche 70122 230 Line	6	2c_LF06	Boone 70061-Midwayps 70286 230 Line
7	2c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	2c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	2c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	2c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	2c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	2c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	2c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	2c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	2c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	2c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	2c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	2c_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct		Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70250	LAJUNTAW	69.0	712	70249	LAJUNTAW	115.0	712	1		25.0 M																			17	1.027

Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

### Transmission Line Multi-case Overload Summary

Base Case 05ha1sa-3c - DC Power = -210 MW(Export), dc bus voltage at 1.022 p.u.

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	2c_LF01	Base Case (all in service)	2	3c_LF02_bx	Lamar Co 70254-Boone 70061 230 Line - PDC=-48 MW
3	2c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	2c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	2c_LF05	Boone 70061-Comanche 70122 230 Line	6	2c_LF06	Boone 70061-Midwayps 70286 230 Line
7	2c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	2c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	2c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	2c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	2c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	2c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	2c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	2c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	2c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	2c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	2c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	2c_LF22	Comanche Generator #1 70119

no transmission lines in the selected area(s) and with the selected voltage level(s) have overloads greater than the criteria

## Multi-case Voltage Summary

**Base Case 05ha1sa-4c - DC Power = 50 MW(Import), Wind Farm = 160 MW, dc bus voltage at 1.04 p.u.**

**Zones for the criteria check are:**

**704,712**

**Minimum bus voltage level 115.0 kV**

**Minimum voltage filter = 0.95 p.u.**

**Maximum voltage filter = 1.05 p.u.**

**Based on N-1 contingency power flow criteria**

Case no	Case Id	Case Description	Case Case Id	Case Description
	1 4c_LF01	Base Case (all in service)	2 4c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
	3 4c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4 4c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 4c_LF05	Boone 70061-Comanche 70122 230 Line	6 4c_LF06	Boone 70061-Midwayps 70286 230 Line
	7 4c_LF07	Boone 70061-Boone 70060 230/115 Transf	8 4c_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 4c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10 4c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 4c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12 4c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 4c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14 4c_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 4c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16 4c_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 4c_LF17	Boone 70060-Lajuntat 70247 115 Line	18 4c_LF22	Comanche Generator #1 70119

bus	Bus name	kV	zone	min volts	max volts	Cases where voltage is outside criteria																		Violation count	Actual	
						1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		min volts	max volts
70549	APT MEM	115.0	712	0.95	1.05							x												1	0.926	0.926
70030	APT PARK	115.0	712	0.95	1.05							x												1	0.929	0.929
70031	APT TAP	115.0	712	0.95	1.05							x												1	0.935	0.935
70022	APT TAP2	115.0	712	0.95	1.05							x												1	0.923	0.923
70060	BOONE	115.0	712	0.95	1.05							x												1	0.905	0.905
70158	DOT	115.0	712	0.95	1.05							x												1	0.905	0.905
70159	DOT TAP	115.0	712	0.95	1.05							x												1	0.908	0.908
70247	LAJUNTAT	115.0	712	0.95	1.05							x												1	0.928	0.928
70249	LAJUNTAW	115.0	712	0.95	1.05							x												1	0.843	0.843
70301	NTHRIDGE	115.0	712	0.95	1.05							x												1	0.949	0.949

Identifies the actual minimum voltage.

Identifies the actual maximum voltage.

x denotes a violation; f flags voltages outside of the range.

## Multi-Case Delta Voltage Summary

**Base Case 05ha1sa-4c - DC Power = 50 MW(Import), Wind Farm = 160 MW, dc bus voltage at 1.04 p.u.**

**Zones for the criteria check are:**

**704,712**

**dv = 0.05**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
	1 5c_LF01	Base Case (all in service)		2 5c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
	3 5c_LF03	Lamar Co 70254-Lamar 70560 230 Line		4 5c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 5c_LF05	Boone 70061-Comanche 70122 230 Line		6 5c_LF06	Boone 70061-Midwayps 70286 230 Line
	7 5c_LF07	Boone 70061-Boone 70060 230/115 Transf		8 5c_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 5c_LF09	Comanche 70122-Walsenbg 70459 230 Line		10 5c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 5c_LF11	Midwayps 70286-Midwaybr 73413 230 Line		12 5c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 5c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line		14 5c_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 5c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line		16 5c_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 5c_LF17	Boone 70060-Lajuntat 70247 115 Line		18 5c_LF22	Comanche Generator #1 70119

Bus				Cases that exceeded dv limit																		Violation count	max dv
number	name	kv	zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70022	APT TAP2	115.0	712							X												1	0.086
70030	APT PARK	115.0	712							X												1	0.077
70031	APT TAP	115.0	712							X												1	0.070
70549	APT MEM	115.0	712							X												1	0.081
70060	BOONE	115.0	712							X												1	0.123
70158	DOT	115.0	712							X									X			2	0.116
70159	DOT TAP	115.0	712							X									X			2	0.116
70247	LAJUNTAT	115.0	712							X												2	0.086
70249	LAJUNTAW	115.0	712							X												1	0.132
70301	NTHRIDGE	115.0	712							X												1	0.052

x denotes dv over 0.05 p.u.



### Transformer Multi-case Overload Summary

Base Case 05ha1sa-4c - DC Power = 50 MW(Import), Wind Farm = 160 MW, dc bus voltage at 1.04 p.u.

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	4c_LF01	Base Case (all in service)	2	4c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
3	4c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	4c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	4c_LF05	Boone 70061-Comanche 70122 230 Line	6	4c_LF06	Boone 70061-Midwayps 70286 230 Line
7	4c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	4c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	4c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	4c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	4c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	4c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	4c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	4c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	4c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	4c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	4c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	4c_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct		Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70250	LAJUNTAW	69.0	712	70249	LAJUNTAW	115.0	712	1		25.0 M																			18	1.035
70253	LAMAR CO	115.0	712	70254	LAMAR CO	230.0	712	1		100.0 M																			0	0.992

Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

### Transmission Line Multi-case Overload Summary

Base Case 05ha1sa-4c - DC Power = 50 MW(Import), Wind Farm = 160 MW, dc bus voltage at 1.04 p.u.

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	4c_LF01	Base Case (all in service)	2	4c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
3	4c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	4c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	4c_LF05	Boone 70061-Comanche 70122 230 Line	6	4c_LF06	Boone 70061-Midwayps 70286 230 Line
7	4c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	4c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	4c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	4c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	4c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	4c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	4c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	4c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	4c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	4c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	4c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	4c_LF22	Comanche Generator #1 70119

no transmission lines in the selected area(s) and with the selected voltage level(s) have overloads greater than the criteria

## Multi-case Voltage Summary

Base Case 05ha1sa-5c - DC Power = -210 MW(Export), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.

Zones for the criteria check are:

704,712

Minimum bus voltage level 115.0 kV

Minimum voltage filter = 0.95 p.u.

Maximum voltage filter = 1.05 p.u.

Based on N-1 contingency power flow criteria

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	5c_LF01	Base Case (all in service)	2	5c_LF02	Lamar Co 70254-Boone 70061 230 Line
3	5c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	5c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	5c_LF05	Boone 70061-Comanche 70122 230 Line	6	5c_LF06	Boone 70061-Midwayps 70286 230 Line
7	5c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	5c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	5c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	5c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	5c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	5c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	5c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	5c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	5c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	5c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	5c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	5c_LF22	Comanche Generator #1 70119

bus	Bus name	kV	zone	min volts	max volts	Cases where voltage is outside criteria																		Violation count	Actual	
						1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		min volts	max volts
70122	COMANCHE	230.0	704	0.95	1.05											x								1	1.050	1.050
70549	APT MEM	115.0	712	0.95	1.05							x												1	0.923	0.923
70030	APT PARK	115.0	712	0.95	1.05							x												1	0.925	0.925
70031	APT TAP	115.0	712	0.95	1.05							x												1	0.932	0.932
70022	APT TAP2	115.0	712	0.95	1.05							x												1	0.920	0.920
70060	BOONE	115.0	712	0.95	1.05							x												1	0.902	0.902
70158	DOT	115.0	712	0.95	1.05							x												1	0.903	0.903
70159	DOT TAP	115.0	712	0.95	1.05							x												1	0.905	0.905
70247	LAJUNTAT	115.0	712	0.95	1.05		x					x												2	0.935	0.937
70249	LAJUNTAW	115.0	712	0.95	1.05		x					x												2	0.841	0.950
70301	NTHRIDGE	115.0	712	0.95	1.05							x												1	0.947	0.947
70452	VILAS	115.0	712	0.95	1.05															x				1	1.052	1.052

Identifies the actual minimum voltage.

Identifies the actual maximum voltage.

x denotes a violation; f flags voltages outside of the range.

## Multi-Case Delta Voltage Summary

**Base Case 05ha1sa-5c - DC Power = -210 MW(Export), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.**

**Zones for the criteria check are:**

**704,712**

**dv = 0.05**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
	1 5c_LF01	Base Case (all in service)		2 5c_LF02	Lamar Co 70254-Boone 70061 230 Line
	3 5c_LF03	Lamar Co 70254-Lamar 70560 230 Line		4 5c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
	5 5c_LF05	Boone 70061-Comanche 70122 230 Line		6 5c_LF06	Boone 70061-Midwayps 70286 230 Line
	7 5c_LF07	Boone 70061-Boone 70060 230/115 Transf		8 5c_LF08	Comanche 70122-Midwayps 70286 230 Line
	9 5c_LF09	Comanche 70122-Walsenbg 70459 230 Line		10 5c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
	11 5c_LF11	Midwayps 70286-Midwaybr 73413 230 Line		12 5c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
	13 5c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line		14 5c_LF14	Lamar Co 70253-Vilas 70452 115 Line
	15 5c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line		16 5c_LF16	Boone 70060-Dot Tap 70159 115 Line
	17 5c_LF17	Boone 70060-Lajuntat 70247 115 Line		18 5c_LF22	Comanche Generator #1 70119

Bus				Cases that exceeded dv limit																		Violation	
number	name	kv	zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	count	max dv
70022	APT TAP2	115.0	712							X												1	0.090
70030	APT PARK	115.0	712							X												1	0.080
70031	APT TAP	115.0	712							X												1	0.073
70549	APT MEM	115.0	712							X												1	0.085
70060	BOONE	115.0	712							X												1	0.124
70158	DOT	115.0	712							X									X			2	0.118
70159	DOT TAP	115.0	712							X									X			2	0.117
70247	LAJUNTAT	115.0	712		X					X												2	0.080
70249	LAJUNTAW	115.0	712							X												1	0.133
70301	NTHRIDGE	115.0	712							X												1	0.056

x denotes dv over 0.05 p.u.

### Transformer Multi-case Overload Summary

**Base Case 05ha1sa-5c - DC Power = -210 MW(Export), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.**

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	5c_LF01	Base Case (all in service)	2	5c_LF02	Lamar Co 70254-Boone 70061 230 Line
3	5c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	5c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	5c_LF05	Boone 70061-Comanche 70122 230 Line	6	5c_LF06	Boone 70061-Midwayps 70286 230 Line
7	5c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	5c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	5c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	5c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	5c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	5c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	5c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	5c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	5c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	5c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	5c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	5c_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct		Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70060	BOONE	115.0	712	70061	BOONE	230.0	712	1		150.0 M																			0	0.992
70250	LAJUNTAW	69.0	712	70249	LAJUNTAW	115.0	712	1		25.0 M																			18	1.035

Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

### Transmission Line Multi-case Overload Summary

Base Case 05ha1sa-5c - DC Power = -210 MW(Export), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.

Zones for the criteria check are:

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	5c_LF01	Base Case (all in service)	2	5c_LF02	Lamar Co 70254-Boone 70061 230 Line
3	5c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	5c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	5c_LF05	Boone 70061-Comanche 70122 230 Line	6	5c_LF06	Boone 70061-Midwayps 70286 230 Line
7	5c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	5c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	5c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	5c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	5c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	5c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	5c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	5c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	5c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	5c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	5c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	5c_LF22	Comanche Generator #1 70119

no transmission lines in the selected area(s) and with the selected voltage level(s) have overloads greater than the criteria

## Multi-case Voltage Summary

**Base Case 05ha1sa-6c - DC Power = 210 MW(Import), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.**

**Zones for the criteria check are:**

**704,712**

**Minimum bus voltage level 115.0 kV**

**Minimum voltage filter = 0.95 p.u.**

**Maximum voltage filter = 1.05 p.u.**

**Based on N-1 contingency power flow criteria**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	6c_LF01	Base Case (all in service)	2	6c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
3	6c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	6c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	6c_LF05	Boone 70061-Comanche 70122 230 Line	6	6c_LF06	Boone 70061-Midwayps 70286 230 Line
7	6c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	6c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	6c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	6c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	6c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	6c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	6c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	6c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	6c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	6c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	6c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	6c_LF22	Comanche Generator #1 70119

bus	Bus name	kV	zone	min volts	max volts	Cases where voltage is outside criteria																		Violation count	Actual	
						1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		min volts	max volts
70549	APT MEM	115.0	712	0.95	1.05							x												1	0.909	0.909
70030	APT PARK	115.0	712	0.95	1.05							x												1	0.913	0.913
70031	APT TAP	115.0	712	0.95	1.05							x												1	0.920	0.920
70022	APT TAP2	115.0	712	0.95	1.05							x												1	0.906	0.906
70060	BOONE	115.0	712	0.95	1.05							x												1	0.883	0.883
70158	DOT	115.0	712	0.95	1.05							x												1	0.885	0.885
70159	DOT TAP	115.0	712	0.95	1.05							x												1	0.888	0.888
70247	LAJUNTAT	115.0	712	0.95	1.05							x												1	0.898	0.898
70249	LAJUNTAW	115.0	712	0.95	1.05					x		x												2	0.822	0.937
70301	NTHRIDGE	115.0	712	0.95	1.05							x												1	0.937	0.937

Identifies the actual minimum voltage.

Identifies the actual maximum voltage.

x denotes a violation; f flags voltages outside of the range.

## Multi-Case Delta Voltage Summary

**Base Case 05ha1sa-6c - DC Power = 210 MW(Import), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.**

**Zones for the criteria check are:**

**704,712**

**minimum voltage level 115.0 kV**

**Based on N-1 contingency power flow criteria**

**dv = 0.05 p.u.**

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	6c_LF01	Base Case (all in service)	2	6c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
3	6c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	6c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	6c_LF05	Boone 70061-Comanche 70122 230 Line	6	6c_LF06	Boone 70061-Midwayps 70286 230 Line
7	6c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	6c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	6c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	6c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	6c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	6c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	6c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	6c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	6c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	6c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	6c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	6c_LF22	Comanche Generator #1 70119

number	Bus name	kV	zone	Cases that exceeded dv limit																		Violation count	max dv
				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70022	APT TAP2	115.0	712							X												1	0.098
70030	APT PARK	115.0	712							X												1	0.086
70031	APT TAP	115.0	712							X												1	0.078
70549	APT MEM	115.0	712							X												1	0.092
70060	BOONE	115.0	712							X												1	0.141
70158	DOT	115.0	712							X									X			2	0.132
70159	DOT TAP	115.0	712							X									X			2	0.132
70247	LAJUNTAT	115.0	712							X												1	0.101
70249	LAJUNTAW	115.0	712							X												1	0.151
70301	NTHRIDGE	115.0	712							X												1	0.059

x denotes dv over 0.05 p.u.



### Transformer Multi-case Overload Summary

Zones for the criteria check are: **Base Case 05ha1sa-6c - DC Power = 210 MW(Import), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.**  
**704,712**  
 Branch rating level for overload assesment = 0  
 Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.  
 Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	4c_LF01	Base Case (all in service)	2	4c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
3	4c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	4c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	4c_LF05	Boone 70061-Comanche 70122 230 Line	6	4c_LF06	Boone 70061-Midwayps 70286 230 Line
7	4c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	4c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	4c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	4c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	4c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	4c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	4c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	4c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	4c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	4c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	4c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	6c_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct		Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70250	LAJUNTAW	69.0	712	70249	LAJUNTAW	115.0	712	1		25.0 M																			17	1.021
70253	LAMAR CO	115.0	712	70254	LAMAR CO	230.0	712	1		100.0 M																			0	0.991

Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

### Transmission Line Multi-case Overload Summary

Zones for the criteria check are:

Base Case 05ha1sa-6c - DC Power = 210 MW(Import), Wind Farm = 160 MW, dc bus voltage 1.04 p.u.

704,712

Branch rating level for overload assesment = 0

Minimum load on branch (p.u. of rating )to be reported = 0.98 p.u.

Minimum bus voltage level 115.0 kV

Case no	Case Id	Case Description	Case no	Case Id	Case Description
1	4c_LF01	Base Case (all in service)	2	4c_LF02c	Lamar Co 70254-Boone 70061 230 Line - PDC=-60 MW
3	4c_LF03	Lamar Co 70254-Lamar 70560 230 Line	4	4c_LF04	Lamar Co 70254-Lamar 70253 230/115 Transf
5	4c_LF05	Boone 70061-Comanche 70122 230 Line	6	4c_LF06	Boone 70061-Midwayps 70286 230 Line
7	4c_LF07	Boone 70061-Boone 70060 230/115 Transf	8	4c_LF08	Comanche 70122-Midwayps 70286 230 Line
9	4c_LF09	Comanche 70122-Walsenbg 70459 230 Line	10	4c_LF10	Comanche 70122-Comanche 70121 230/115 Transf
11	4c_LF11	Midwayps 70286-Midwaybr 73413 230 Line	12	4c_LF12	Midwayps 70286-Midwayps 70285 230/115 Transf
13	4c_LF13	Lajuntat 70247-Wilow Ck 70472 115 Line	14	4c_LF14	Lamar Co 70253-Vilas 70452 115 Line
15	4c_LF15	Lamar co 70253-Wilow Ck 70472 115 Line	16	4c_LF16	Boone 70060-Dot Tap 70159 115 Line
17	4c_LF17	Boone 70060-Lajuntat 70247 115 Line	18	6c_LF22	Comanche Generator #1 70119

From Bus				To Bus				cct	sect	Base rating	Cases where loading exceeds criteria																		O/L count	Max Load
bus	name	kV	zone	bus	name	kV	zone				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18		
70336	PUEB-TAP	115.0	704	70456	W.STATON	115.0	712	1	1	386.6 A																1	1.048			


Indicates loads which are greater than 1 pu

Indicates loads which are equal to the maximum load

Indicates loads which are greater than 1 pu and equal to the maximum load

**Appendix 4– Load Flow Study Result  
(+50/-20 MVAR AC Voltage Control Capability of HVDC Link,  
Export 210 MW from WECC to SPP System,  
Contingency 5 - Loss of BOONE-COMANCHE 230 Line)**

# Zones 704 & 712, 230kV & 115kV System



## **Appendix 5.1– Transient Stability Study Results (Original Base Case – Without HVDC Link)**




plot#1

Mon Apr 15 11:37:07 2002

fault02-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.6000	O	vbus	70061	BOONE	230.00	1	1.1000
0.6000	+	vbus	70122	COMANCHE	230.00	1	1.1000
0.6000	*	vbus	70254	LAMAR CO	230.00	1	1.1000
0.6000	#	vbug	70560	LAMAR DC	230.00	1	1.1000
0.6000	X	vbus	70286	MIDWAYPS	230.00	1	1.1000

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 3 cycle fault at LAMAR CO(70254) 230kV bus

open 230kV line LAMAR CO(70254) - BOONE(70061) after fault cleared




PLOT#2

Mon Apr 15 11:37:08 2002

fault02-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.6000	○	vbus	70060	BOONE	115.00	1	1.1000
0.6000	+	vbus	70247	LAJUNTAT	115.00	1	1.1000
0.6000	*	vbus	70253	LAMAR CO	115.00	1	1.1000
0.6000	#	vbus	70472	WILLOW CK	115.00	1	1.1000

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 3 cycle fault at LAMAR CO(70254) 230kV bus

open 230kV line LAMAR CO(70254) - BOONE(70061) after fault cleared




PLOT#5

Mon Sep 09 11:49:10 2002

fault02-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	○	ang	70119	COMAN 1	24.00	1	100.00
0.0000	+	ang	70133	CTY LAM	14.40	1	100.00
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 3 cycle fault at LAMAR C0(70254) 230kV bus

open 230kV line LAMAR C0(70254) - BOONE(70061) after fault cleared






plot#1

Fri Apr 12 11:01:22 2002

fault03-1b.chf

C:\save\366-electranix\stab\05ha1sa-



WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 6 cycle fault at LAMAR CO(70253)115kV bus

open 115 kV line LAMAR CO(70253) - WILLOW CK(70472) after fault clearing




PLOT#2

Fri Apr 12 11:01:22 2002

fault03-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.6000	○	vbus	70060 BOONE	115.00	1	1.1000
0.6000	+	vbus	70247 LAJUNTAT	115.00	1	1.1000
0.6000	*	vbus	70253 LAMAR CO	115.00	1	1.1000
0.6000	#	vbus	70472 WILLOW CK	115.00	1	1.1000

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 6 cycle fault at LAMAR CO(70253)115kV bus

open 115 kV line LAMAR CO(70253) - WILLOW CK(70472) after fault clearing




PLOT#5

Mon Sep 09 11:51:32 2002

fault03-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	○	ang	70119 COMAN 1	24.00	1	100.00
0.0000	+	ang	70133 CTY LAM	14.40	1	100.00
0.0000	*	ang	73507 NIXON1CC	18.00	1	100.00

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 6 cycle fault at LAMAR C0(70253)115kV bus

open 115 kV line LAMAR C0(70253) - WILLOW CK(70472) after fault clearing




plot#1

Fri Apr 12 11:35:58 2002

fault04-1b.chf

C:\save\366-electranix\stab\05ha1sa-



Time, sec.							
0.7000	O	vbus	70061	BOONE	230.00	1	1.1000
0.7000	+	vbus	70122	COMANCHE	230.00	1	1.1000
0.7000	*	vbus	70254	LAMAR CO	230.00	1	1.1000
0.7000	#	vbus	70560	LAMAR DC	230.00	1	1.1000
0.7000	X	vbus	70286	MIDWAYPS	230.00	1	1.1000

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus

open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




PLOT#2

Fri Apr 12 11:35:58 2002

fault04-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.7000	○	vbus	70060	BOONE	115.00	1	1.1000
0.7000	+	vbus	70247	LAJUNTAT	115.00	1	1.1000
0.7000	*	vbus	70253	LAMAR CO	115.00	1	1.1000
0.7000	#	vbus	70472	WILLOW CK	115.00	1	1.1000

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus

open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




PLOT#5

Mon Sep 09 11:54:19 2002

fault04-1b.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	O	ang	70119	COMAN 1	24.00	1	100.00
0.0000	+	ang	70133	CTY LAM	14.40	1	100.00
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

WESTERN SYSTEMS COORDINATING COUNCIL

2005 HA1-SA APPROVED BASE CASE

NOVEMBER 6, 2001, Case 05ha1sa-1b

Changed 70460 WALSH 69KV SVD type from 4 to 2 (continuous)

Boone 230/115kV xformer in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus

open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing

## **Appendix 5.2– Transient Stability Study Results (HVDC Link Importing 210 MW into WSCC System)**




plot#1

Wed Apr 10 11:53:12 2002

fault01a-2c.chf

C:\save\366-electranix\stab\05halsa-2c\05ha



0.4000	O	vbus	70061	BOONE	230.00	1	1.4000
0.4000	+	vbus	70122	COMANCHE	230.00	1	1.4000
0.4000	*	vbus	70254	LAMAR CO	230.00	1	1.4000
0.4000	#	vbug	70560	LAMAR DC	230.00	1	1.4000
0.4000	X	vbus	70286	MIDWAYPS	230.00	1	1.4000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

switch off Load at 70560 LAMAR DC 230kV bus simulate as dc block permanently






PLOT#2

Wed Apr 10 11:53:12 2002

fault01a-2c.chf

C:\save\366-electranix\stab\05halsa-2c\05ha



0.4000	O	vbus	70060	BOONE	115.00	1	1.4000
0.4000	+	vbus	70247	LAJUNTAT	115.00	1	1.4000
0.4000	*	vbus	70253	LAMAR CO	115.00	1	1.4000
0.4000	#	vbus	70472	WILOW CK	115.00	1	1.4000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

switch off Load at 70560 LAMAR DC 230kV bus simulate as dc block permanently




PLOT#5

Mon Sep 09 13:29:29 2002

fault01ai-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



Time, sec.						
0.0000	O	ang	70119 COMAN 1	24.00	1	100.00
0.0000	+	ang	70133 CTY LAM	14.40	1	200.00
-50.00	*	ang	73507 NIXON1CC	18.00	1	50.000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

switch off Load at 70560 LAMAR DC 230kV bus simulate as dc block permanently




plot#1

Wed Apr 10 13:52:47 2002

fault01bi-2c.chf

C:\save\366-electranix\stab\05halsa-2c\05ha



0.4000	O	vbus	70061	BOONE	230.00	1	1.4000
0.4000	+	vbus	70122	COMANCHE	230.00	1	1.4000
0.4000	*	vbus	70254	LAMAR CO	230.00	1	1.4000
0.4000	#	vbug	70560	LAMAR DC	230.00	1	1.4000
0.4000	X	vbus	70286	MIDWAYPS	230.00	1	1.4000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

switch off Load at LAMAR DC 230kV(70560) bus simulate as dc block

trip all shunt capacitors at LAMAR DC(70560) 230kV bus after 5 cycles




PLOT#2

Wed Apr 10 13:52:47 2002

fault01bi-2c.chf

C:\save\366-electranix\stab\05halsa-2c\05ha



0.4000	O	vbus	70060 BOONE	115.00	1	1.4000
0.4000	+	vbus	70247 LAJUNTAT	115.00	1	1.4000
0.4000	*	vbus	70253 LAMAR CO	115.00	1	1.4000
0.4000	#	vbus	70472 WILOW CK	115.00	1	1.4000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

switch off Load at LAMAR DC 230kV(70560) bus simulate as dc block

trip all shunt capacitors at LAMAR DC(70560) 230kV bus after 5 cycles




PLOT#5

Mon Sep 09 13:36:40 2002

fault01bi-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



Time, sec.							
0.0000	O	ang	70119	COMAN 1	24.00	1	100.00
0.0000	+	ang	70133	CTY LAM	14.40	1	200.00
-50.00	*	ang	73507	NIXON1CC	18.00	1	50.000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20Mvar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

switch off Load at LAMAR DC 230kV(70560) bus simulate as dc block

trip all shunt capacitors at LAMAR DC(70560) 230kV bus after 5 cycles




plot#1

Mon Apr 15 12:38:50 2002

fault02ib-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.4000	O	vbus	70061	BOONE	230.00	1	1.4000
0.4000	+	vbus	70122	COMANCHE	230.00	1	1.4000
0.4000	*	vbus	70254	LAMAR C0	230.00	1	1.4000
0.4000	#	vbug	70560	LAMAR DC	230.00	1	1.4000
0.4000	X	vbus	70286	MIDWAYPS	230.00	1	1.4000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

3 phase 3 cycle fault at LAMAR C0(70254) 230kV bus

open 230kV line LAMAR C0(70254) - BOONE(70061) after fault cleared

dc reduced to -100 MW (import)




PLOT#2

Mon Apr 15 12:38:50 2002

fault02ib-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.4000	O	vbus	70060 BOONE	115.00	1	1.4000
0.4000	+	vbus	70247 LAJUNTAT	115.00	1	1.4000
0.4000	*	vbus	70253 LAMAR CO	115.00	1	1.4000
0.4000	#	vbus	70472 WILLOW CK	115.00	1	1.4000

2005 HA1-SA-2C: 210MW import from SPP  
dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar  
Reduced 210MW generation in zones 700 & 706  
Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)  
Boone 230/115kV transformer in type 12

3 phase 3 cycle fault at LAMAR CO(70254) 230kV bus  
open 230kV line LAMAR CO(70254) - BOONE(70061) after fault cleared  
dc reduced to -100 MW (import)




PLOT#5

Mon Sep 09 13:48:25 2002

fault02ib-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.0000	○	ang	70119	COMAN 1	24.00	1	100.00
0.0000	+	ang	70133	CTY LAM	14.40	1	200.00
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

2005 HA1-SA-2C: 210MW import from SPP  
dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20Mvar  
Reduced 210MW generation in zones 700 & 706  
Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)  
Boone 230/115kV transformer in type 12

3 phase 3 cycle fault at LAMAR C0(70254) 230kV bus  
open 230kV line LAMAR C0(70254) - BOONE(70061) after fault cleared  
dc reduced to -100 MW (import)






plot#1

Thu Apr 11 09:10:51 2002

fault03i-2c.chf

C:\save\366-electranix\stab\05halsa-2c\05ha



0.6000	O	vbus	70061	BOONE	230.00	1	1.1000
0.6000	+	vbus	70122	COMANCHE	230.00	1	1.1000
0.6000	*	vbus	70254	LAMAR CO	230.00	1	1.1000
0.6000	#	vbug	70560	LAMAR DC	230.00	1	1.1000
0.6000	X	vbus	70286	MIDWAYPS	230.00	1	1.1000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

3 phase 6 cycle fault at LAMAR CO(70253)115kV bus

open 115 kV line LAMAR CO(70253) - WILLOW CK(70472) after fault clearing




PLOT#2

Thu Apr 11 09:10:51 2002

fault03i-2c.chf

C:\save\366-electranix\stab\05halsa-2c\05ha



0.6000	O	vbus	70060 BOONE	115.00	1	1.1000
0.6000	+	vbus	70247 LAJUNTAT	115.00	1	1.1000
0.6000	*	vbus	70253 LAMAR CO	115.00	1	1.1000
0.6000	#	vbus	70472 WILOW CK	115.00	1	1.1000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

3 phase 6 cycle fault at LAMAR CO(70253)115kV bus

open 115 kV line LAMAR CO(70253) - WILOW CK(70472) after fault clearing




PLOT#5

Mon Sep 09 13:50:29 2002

fault03i-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.0000	○	ang	70119 COMAN 1	24.00	1	100.00
0.0000	+	ang	70133 CTY LAM	14.40	1	100.00
0.0000	*	ang	73507 NIXON1CC	18.00	1	100.00

2005 HA1-SA-2C: 210MW import from SPP  
dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20Mvar  
Reduced 210MW generation in zones 700 & 706  
Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)  
Boone 230/115kV transformer in type 12

3 phase 6 cycle fault at LAMAR C0(70253)115kV bus  
open 115 kV line LAMAR C0(70253) - WILLOW CK(70472) after fault clearing




plot#1

Fri Apr 12 11:59:24 2002

fault04i-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.6000	O	vbus	70061	BOONE	230.00	1	1.1000
0.6000	+	vbus	70122	COMANCHE	230.00	1	1.1000
0.6000	*	vbus	70254	LAMAR CO	230.00	1	1.1000
0.6000	#	vbug	70560	LAMAR DC	230.00	1	1.1000
0.6000	X	vbus	70286	MIDWAYPS	230.00	1	1.1000

2005 HA1-SA-2C: 210MW import from SPP

dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar

Reduced 210MW generation in zones 700 & 706

Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)

Boone 230/115kV transformer in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus

open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




PLOT#2

Fri Apr 12 11:59:24 2002

fault04i-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.6000	O	vbus	70060 BOONE	115.00	1	1.1000
0.6000	+	vbus	70247 LAJUNTAT	115.00	1	1.1000
0.6000	*	vbus	70253 LAMAR CO	115.00	1	1.1000
0.6000	#	vbus	70472 WILLOW CK	115.00	1	1.1000

2005 HA1-SA-2C: 210MW import from SPP  
dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20MVar  
Reduced 210MW generation in zones 700 & 706  
Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)  
Boone 230/115kV transformer in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus  
open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




PLOT#5

Mon Sep 09 13:53:01 2002

fault04i-2c.chf

C:\save\366-electranix\stab\05ha1sa-2



0.0000	○	ang	70119	COMAN 1	24.00	1	100.00
20.000	+	ang	70133	CTY LAM	14.40	1	100.00
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

2005 HA1-SA-2C: 210MW import from SPP  
dc bus voltage hold at 1.04 p.u. with Qmx=50Mvar & Qmn=-20Mvar  
Reduced 210MW generation in zones 700 & 706  
Modified 70460 WALSH 69kV SVD type from 4 to 2 (continuous)  
Boone 230/115kV transformer in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus  
open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing

## **Appendix 5.3– Transient Stability Study Results (HVDC Link Exporting 210 MW from WSCC System)**




plot#1

Thu Apr 11 11:31:03 2002

fault01ae-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.5000	O	vbus	70061	BOONE	230.00	1	1.5000
0.5000	+	vbus	70122	COMANCHE	230.00	1	1.5000
0.5000	*	vbus	70254	LAMAR CO	230.00	1	1.5000
0.5000	#	vbug	70560	LAMAR DC	230.00	1	1.5000
0.5000	X	vbus	70286	MIDWAYPS	230.00	1	1.5000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

switch off Load at 70560 LAMAR DC 230kV bus simulate as dc block permanently






PLOT#2

Thu Apr 11 11:31:03 2002

fault01ae-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.5000	O	vbus	70060	BOONE	115.00	1	1.5000
0.5000	+	vbus	70247	LAJUNTAT	115.00	1	1.5000
0.5000	*	vbus	70253	LAMAR CO	115.00	1	1.5000
0.5000	#	vbus	70472	WILLOW CK	115.00	1	1.5000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

switch off Load at 70560 LAMAR DC 230kV bus simulate as dc block permanently




PLOT#5

Mon Sep 09 14:01:23 2002

fault01ae-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	○	ang	70119	COMAN 1	24.00	1	100.00
0.0000	+	ang	70133	CTY LAM	14.40	1	200.00
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

switch off Load at 70560 LAMAR DC 230kV bus simulate as dc block permanently




plot#1

Thu Apr 11 11:44:10 2002

fault01be-3c.chf

C:\save\366-electranix\stab\05ha1sa-



2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

switch off Load at LAMAR DC 230kV(70560) bus simulate as dc block

trip all shunt capacitors at LAMAR DC(70560) 230kV bus after 5 cycles




PLOT#2

Thu Apr 11 11:44:10 2002

fault01be-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.5000	○	vbus	70060 BOONE	115.00	1	1.5000
0.5000	+	vbus	70247 LAJUNTAT	115.00	1	1.5000
0.5000	*	vbus	70253 LAMAR CO	115.00	1	1.5000
0.5000	#	vbus	70472 WILLOW CK	115.00	1	1.5000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

switch off Load at LAMAR DC 230kV(70560) bus simulate as dc block

trip all shunt capacitors at LAMAR DC(70560) 230kV bus after 5 cycles




PLOT#5

Mon Sep 09 14:07:31 2002

fault01be-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	○	ang	70119 COMAN 1	24.00	1	100.00
0.0000	+	ang	70133 CTY LAM	14.40	1	200.00
0.0000	*	ang	73507 NIXON1CC	18.00	1	100.00

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

switch off Load at LAMAR DC 230kV(70560) bus simulate as dc block

trip all shunt capacitors at LAMAR DC(70560) 230kV bus after 5 cycles




plot#1

Thu Apr 11 16:33:49 2002

fault02e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.4000	O	vbus	70061	BOONE	230.00	1	1.4000
0.4000	+	vbus	70122	COMANCHE	230.00	1	1.4000
0.4000	*	vbus	70254	LAMAR C0	230.00	1	1.4000
0.4000	#	vbug	70560	LAMAR DC	230.00	1	1.4000
0.4000	X	vbus	70286	MIDWAYPS	230.00	1	1.4000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 3 cycle fault at LAMAR C0(70254) 230kV bus

open 230kV line LAMAR C0(70254) - BOONE(70061) after fault cleared

dc reduced to 48 MW (export), 52Mvar capacitor left at dc bus




PLOT#2

Thu Apr 11 16:33:49 2002

fault02e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.4000	○	vbus	70060 BOONE	115.00	1	1.4000
0.4000	+	vbus	70247 LAJUNTAT	115.00	1	1.4000
0.4000	*	vbus	70253 LAMAR CO	115.00	1	1.4000
0.4000	#	vbus	70472 WILLOW CK	115.00	1	1.4000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 3 cycle fault at LAMAR CO(70254) 230kV bus

open 230kV line LAMAR CO(70254) - BOONE(70061) after fault cleared

dc reduced to 48 MW (export), 52Mvar capacitor left at dc bus




PLOT#5

Mon Sep 09 14:13:42 2002

fault02e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	○	ang	70119	COMAN 1	24.00	1	100.00
-10.00	+	ang	70133	CTY LAM	14.40	1	90.000
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 3 cycle fault at LAMAR C0(70254) 230kV bus

open 230kV line LAMAR C0(70254) - BOONE(70061) after fault cleared

dc reduced to 48 MW (export), 52Mvar capacitor left at dc bus






plot#1

Thu Apr 11 13:33:38 2002

fault03e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 6 cycle fault at LAMAR CO(70253)115kV bus

open 115 kV line LAMAR CO(70253) - WILLOW CK(70472) after fault clearing




PLOT#2

Thu Apr 11 13:33:38 2002

fault03e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.6000	○	vbus	70060 BOONE	115.00	1	1.1000
0.6000	+	vbus	70247 LAJUNTAT	115.00	1	1.1000
0.6000	*	vbus	70253 LAMAR CO	115.00	1	1.1000
0.6000	#	vbus	70472 WILLOW CK	115.00	1	1.1000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 6 cycle fault at LAMAR CO(70253)115kV bus

open 115 kV line LAMAR CO(70253) - WILLOW CK(70472) after fault clearing




PLOT#5

Mon Sep 09 14:16:07 2002

fault03e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	○	ang	70119 COMAN 1	24.00	1	100.00
0.0000	+	ang	70133 CTY LAM	14.40	1	100.00
0.0000	*	ang	73507 NIXON1CC	18.00	1	100.00

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 6 cycle fault at LAMAR C0(70253)115kV bus

open 115 kV line LAMAR C0(70253) - WILLOW CK(70472) after fault clearing




plot#1

Fri Apr 12 12:16:27 2002

fault04e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.6000	O	vbus	70061 BOONE	230.00	1	1.1000
0.6000	+	vbus	70122 COMANCHE	230.00	1	1.1000
0.6000	*	vbus	70254 LAMAR CO	230.00	1	1.1000
0.6000	#	vbug	70560 LAMAR DC	230.00	1	1.1000
0.6000	X	vbus	70286 MIDWAYPS	230.00	1	1.1000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus

open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




PLOT#2

Fri Apr 12 12:16:27 2002

fault04e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.6000	○	vbus	70060 BOONE	115.00	1	1.1000
0.6000	+	vbus	70247 LAJUNTAT	115.00	1	1.1000
0.6000	*	vbus	70253 LAMAR CO	115.00	1	1.1000
0.6000	#	vbus	70472 WILLOW CK	115.00	1	1.1000

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105

Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus

open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




PLOT#5

Mon Sep 09 14:17:53 2002

fault04e-3c.chf

C:\save\366-electranix\stab\05ha1sa-



0.0000	O	ang	70119	COMAN 1	24.00	1	100.00
0.0000	+	ang	70133	CTY LAM	14.40	1	80.000
0.0000	*	ang	73507	NIXON1CC	18.00	1	100.00

2005 HA1-SA-3C: 210MW export from WSCC to SPP

dc bus voltage hold at 1.022 p.u., Qdcmx=50MVar & Qdcmn=-20MVar

Dispatch generator 70589 for 190MW and 20MW additon to generator 70105






Modified 70460 WALSH 69kV SVD from type 4 to 2 (continuous)

Boone 230/115kV xfmr in type 12

3 phase 6 cycle fault at LAJUNTAT(70247) 115kV bus


open 115 kV line LAJUNTAT(70247) - WILLOW CK(70472) after fault clearing




## **Appendix 6– PSCAD Transient Circuit (System and HVDC Controls Diagrams)**

























The Time is:  
12:15:4



The Date is:  
4/15/2002





## **Appendix 7– PSCAD Transient Study Results**















PSCAD Case 2i - Import 210 MW, Fault on Lamar-Boone 230, Line Trip after 3 cycles (52.5 MVARs of Filters Left On, Power Order Reduction to 48 MW)











PSCAD Case 2e - Export 210 MW, Fault on Lamar-Boone 230, Line Trip after 3 cycles (78.75 MVARs of Filters Left On, Power Order Reduction to -48 MW)

