

Vail/Eagle Valley Capacitor Bank Sizing Study

October 17, 2022

A. Executive Summary

This study builds upon the previous studies that resulted in the 115kV line rebuilds for Circuits No. 9254 and 9257 and the Avon-Gilman line build projects. Capacitive voltage support for the study area was deemed necessary during these previous studies. In 2015, the Public Utilities Commission of Colorado determined building of the Avon-Gilman line and adding a 45 MVAR capacitor bank at Vail substation was in the ordinary course of business.

This follow-on study was conducted to determine updated requirements for capacitive voltage support in an N-2 condition (loss of 115kV) in the Vail/Eagle Valley out to 2040. The N-2 condition would result in the loss of both 115kV lines from Wolcott to Beaver Creek West and Vail substations. Holy Cross (HCE), a wholesale customer, services the loads from Avon, Beaver Creek West, Vail, and Wolcott substations.

The study found under the N-2 condition (loss of 115 kV) a need for capacitive support of 15 to 25 MVAR for summer peak loads and 65 to 75 MVAR for winter peak loads. Capacitive support under these scenarios restored the study area bus voltages to nominal operating levels (0.95 to 1.05). The N-0 condition, or normal operating condition, did not require capacitive support for any of the study load scenarios.

Transmission Planning recommends a total capacity of 75 MVAR in differing step sizes, having a minimum configuration of 25 MVAR, to be distributed between Beaver Creek West and Vail substations. Capacitor bank location totals and step sizes are detailed below in the Recommendation section. Distributing the total cap bank amount across the study area provides more resiliency in case an event such as a wildfire removed service from one but not both substations.

After sharing initial results with Transmission Operations, a loss of the 230 kV shared corridor to Wolcott substation from both Foidel Creek and Cooley Mesa substations was suggested as a supplemental study. The supplemental study makes the same assumptions as the original study but does not remove any 115 kV lines in the study area and increases the 115 kV service demand by adding the Wolcott load.

An additional 20 – 25 MVAR of capacitive voltage support would be required to support the additional Wolcott load during heavy winter peak scenarios. This brings the total recommended capacitive voltage support to 100 MVAR for the study area. Line overloads did occur with the additional Wolcott load. To address the observed line overloads operational procedures may need to be developed, which are outside the scope of this study.

B. Study Scope

The study was performed to determine the amount of capacitive support necessary to mitigate voltage collapse in the Vail/Eagle Valley resulting from the loss of 115 kV transmission from or at Wolcott Substation and closing of the normally open Avon-Gilman line. Losses include the Wolcott-Beaver Creek West 115kV line (Circuit 8415) and Wolcott-Vail 115kV line (Circuit 8416). The circuits are on separate 115kV structures; however, they are separated by approximately 100 to 200 feet and parallel for 9 miles.

This N-2 condition, "Loss of all Transmission lines on a common Right-of-Way" is considered an Extreme Event [TPL-001-4, Table 1, Extreme Events, 2.b.]. A previous study of the same N-2 condition resulted in the decision to construct the Avon-Gilman 115kV line, uprating of 115 kV Circuits No. 9254 and 9257, and determined a need for capacitive voltage support when the Avon-Gilman line was closed. In 2015 the Public Utility Commission of Colorado found that the Avon-Gilman line and a 45 MVAR cap bank at Vail was found to be in the ordinary course of business through Decision No. C15-0590 and would not require a CPCN.

Continuing and projected economic development and resulting peak loads in the study area indicated a need for an updated study.

This study focused on updating the total MVAR amount, increments, and possible locations of the voltage support required when closing the Avon-Gilman line during an N-2 condition across the loading conditions in the Vail/Eagle Valley.

Beyond the TPL-001-4 requirement, special consideration is being given to this condition for the following reasons:

- Holy Cross (HCE) has expressed concern over the vulnerability and substantial likelihood that such an N-2 condition could occur due to the location and configuration of Circuits No. 8415 and 8416.
- The risk of an Extreme Event and resulting N-2 condition is abnormally high due to the increased probability of wildfire, avalanche, and landslide and severity of the impact.
 - Depending on the severity of the damage, an outage could remain for a prolonged period, which would be exacerbated by the current lead time of critical materials and challenging terrain.
- The Vail Valley is home to two world class ski resorts and is a major tourist destination. A sustained outage would result in significant economic loss for the state economy and attract international media attention depending on the season and time to restoration to the N-0 condition.
- Xcel customers remain in, move to, and visit Colorado to take advantage of the unique experiences this area provides.

C. Study Cases

The following WECC approved planning cases were used for the study:

- 2033 Heavy Winter 1
- 2033 Heavy Summer 1

These were used as the starting cases for the winter and summer peak scenarios, respectively. The study area, Vail/Eagle Valley, is winter peaking.

To determine capacitive support for light load scenarios, the following study cases were created:

- 2033 Light Winter case was developed by reducing conforming study area loads to 60% of winter peak load demands in the study area
- 2033 Light Summer case was developed by reducing conforming study area loads to 60% of summer peak load demands in the study area.

Load forecasts used in the study area were developed internally and provided by Holy Cross (HCE). The 2033 Heavy Winter 1 and Heavy Summer 1 cases were used for generation and loading outside of the study area.

D. Study Assumptions

The following assumptions were used for the study:

- The Avon-Gilman 115kV line is in-service and closed.
- The Leadville–Climax and Climax-Robinson Rack-Gilman (Circuit No. 9257) line uprate is in-service.
- The Leadville-Robinson Rack (Circuit No. 9254) line uprate is in-service.
- PI data or forecasts were extrapolated to 2042 using a WECC approved 1% year-over-year increase except for the industrial loads, 70281 Mayflower IN and 70114 Climax IN, which are static or non-conforming.
- The forecasted load data, provided by HCE, was capacitive for Beaver Creek West, Vail, and Avon. The capacitive attribute of the loads is representative of extensive underground conductor used to supply load demand.
- The study area is winter peaking.
- The N-2 conditions results in a sustained outage for Circuits No. 8415 and 8416 out of Wolcott removing the lines from Wolcott to Beaver Creek West and Vail, respectively.
- Beaver Creek West, Vail, and Avon will experience total loss of service until the new 115 kV Avon-Gilman line is closed, and the capacitor banks are energized.
- An operational procedure for energizing the Avon-Gilman line is outside the scope of this study.
- After a single event resulting in a N-2 condition, restoration of Circuits No. 8415 and 8416 could take weeks to months, and the study area voltage levels will need to remain between 0.95 to 1.05 pu.

- Siting a capacitor bank at Avon is unreasonable due to footprint constraints at and around the facility.

E. Findings

- No line overloads observed in the N-0 and N-2 condition.
- Capacitive support of 15 to 25 MVAR for summer peak and 65 to 75 MVAR for winter peak restored the study area bus voltages to between 0.95 to 1.05 pu for both the 2033 and 2042 case scenarios.
- The light load scenarios, 60% winter and 60% summer, did not require additional capacitive support to maintain voltage levels between 0.97 to 1.03 pu in the study area.
- The total capacitive compensation, total MVAR, can be configured and distributed between Beaver Creek West and Vail without materially reducing the effectiveness of the total capacitive compensation
 - The total amount of MVAR must meet peak demand
 - The minimum amount of MVAR must be available
- The N-2 condition creates a radial line to Beaver Creek West and Vail resulting in a weak system in the N-2 condition. After Avon-Gilman is energized, significant voltage swings (>5%) were observed when switching in large increments of capacitive support.
 - Mitigation of the observed large voltage swings can be addressed by decreasing the step sizes to reach the total MVAR required.

F. Conclusion

Cap banks are not needed for the N-0 condition. Capacitive compensation is required to restore the system to within normal operating voltage limits (0.95 – 1.05 pu) following a single-event double-line contingency (N-2). A sustained outage will exist until the Avon-Gilman line is closed and the capacitive compensation is energized. An unmitigated system without capacitive compensation in heavily loaded scenarios resulted in voltage collapse in the study area when the Avon-Gilman line was closed.

To maintain maximum operational flexibility and reliability during the single-event double-line outage of Circuits No. 8415 and 8416 capacitive compensation of 65 -75 MVAR and 15 – 25 MVAR compensation is required across Beaver Creek West and Vail for peak winter and summer loads, respectively.

During a sustained outage, significant daily fluctuations are expected in the hourly load profile for the area. Therefore, an automatic voltage control system is recommended to regulate the voltage swings during the N-2 condition.

Step increments within the study area must be divisible to an extent that compensates for the heavy winter versus heavy summer loading whether at one or multiple locations. Smaller step

sizes distributed across the three substations reduce the likelihood of introducing problematic transients into the study area as the capacitive support is energized. Furthermore, if a wildfire creates the N-2 condition and removes service to Vail or Beaver Creek West, cap banks at multiple locations may allow the remaining substation to operate within voltage limits depending on incremental sizing.

An EMTP analysis may be necessary to determine precise cap bank sizing, transient levels, and operating procedures.

G. Recommendations

The alternative sizing and location recommendations are made due to the concern over Sighting and Land Rights limitations at the substations. Smaller increments dispersed across the study area are recommended if reasonable. Automatic voltage controllers (AVSO) to manage switching operations during a sustained outage are recommended.

Preferred Solution (2-substation, expanded):

Total of 75 MVAR installed Cap Bank capacity throughout the Vail Valley in the following configuration:

- 30 MVAR at Beaver Creek West in increments of 5,10, and 15 MVAR
- 30 MVAR at Vail in increments of 5,10, and 15 MVAR
- Additional 15 MVAR step at Beaver Creek West or Vail.

This solution sufficiently supports voltage drop across the Vail Valley. Reduced step size allows for expanded operational flexibility and decreased rapid voltage swings due to the smaller step sizes

Alternative 1 (2-Substation, consolidated):

A combined total of 75 MVAR at Beaver Creek West and Vail with multiple steps at one or both locations. Examples:

- 50 MVAR at Beaver Creek West in increments of 5, 10, 15, and 20 MVAR
- 35 MVAR at Vail in increments of 10 and 25 MVAR

OR

- 50 MVAR at Beaver Creek West in increments of 20 and 30
- 25 MVAR single step at Vail

This alternative maintains operational flexibility and voltages in the study area, while reducing the potential for large voltage swings when energizing the Cap Banks.

Alternative 2 (2-Substation, Single Step):

25 and 50 MVAR single-step cap banks at Beaver Creek West and Vail, the location of either does not materially affect the compensation effectiveness.

This alternative address both the minimum and maximum sizing needed to support voltages in the area; however, this alternative limits operational flexibility. Energizing cap banks of this amount will likely produce large voltage swings and transients.

Planning Engineer: Adrian Horner

Adrian.E.Horner@xcelenergy.com

H. Supplemental Study

After analyzing the results for the initial N-2 condition, Transmission Operations suggested Transmission Planning evaluate the capability of the original 75 MVAR recommended capacitive voltage support if the 230 kV corridor to Wolcott was lost. The supplemental study removes 230 kV service to Wolcott and serves the Wolcott load via an intact 115 kV corridor from Robinson Rack to Wolcott substations.

The addition of the Wolcott load extends the radial 115 kV corridor from Robinson Rack to Wolcott by approximately 11 miles. Loss of both 230 kV circuits from Wolcott substation while paralleling or after they diverge is reasonable due to wildfire risk.

Study Cases: same as above.

Study Assumptions:

- Total loss of 230kV service to Wolcott
 - Loss of the 230kV Cooley Mesa - Wolcott (Circuit No. 5785)
 - Loss of the 230kV Wolcott – Foidel Creek (Circuit No. 5813)
- 115kV service to Wolcott is intact
 - Wolcott – Beaver Creek West (Circuit No. 8415) is intact
 - Wolcott – Vail (Circuit No. 8416) is intact
- The Avon-Gilman 115kV line is in-service and closed.
- The Leadville–Climax and Climax-Robinson Rack-Gilman (Circuit No. 9257) line uprate is in-service.
- The Leadville-Robinson Rack (Circuit No. 9254) line uprate is in-service.
- PI data or forecasts were further extrapolated to 2042 using a WECC approved 1% year-over-year increase except for the industrial loads 70281 Mayflower IN and 70114 Climax IN, which are static or non-conforming.
- The forecasted load data provided by HCE was capacitive for Beaver Creek West, Vail, Avon, and Wolcott. The capacitive attribute of the loads is representative of extensive underground conductor used to supply load demand.
- The 2033 Heavy Summer 1 and 2033 Heavy Winter 1 load values were used for Wolcott
- The study area is winter peaking.
- Beaver Creek West, Vail, Avon, and Wolcott will experience total loss of service until the 115 kV Avon-Gilman line is closed, and the capacitor banks are energized.

- An operational procedure for energizing the Avon-Gilman line is outside the scope of this study.
- After a single event resulting in a N-2 condition, restoration of Circuits No. 5785 and 5813 could take weeks to months, and the study area voltage levels will need to remain between 0.95 to 1.05 pu.
- Siting a capacitor bank at Avon is unreasonable due to footprint constraints at and around the facility.
- A capacitor bank was not placed at Wolcott
 - Access to the cap bank would be lost during the 115kV N-2 condition
 - Wolcott already operates at a higher normal operating voltage in the N-0 condition
 - The two 20 MVAR (40 total) reactor on the 230kV Wolcott bus is off

Findings:

- Line overloads were observed in the N-2 condition during heavy winter loading.
 - 110 - 113% Robinson Rack-Gilman 115kV line (Circuit No. 9257)
 - 108 - 112% Avon-Gilman 115kV line
 - 91 - 100% Climax-Mayflower 115kV line (Circuit No. 8174)
- Capacitive support of 20 to 30 MVAR for summer peak and 85 to 95 MVAR for winter peak restored the study area bus voltages to between 0.95 to 1.05 pu for both the 2033 and 2042 case scenarios depending on the forecasted data set.
- Capacitive support of 75 MVAR raised all bus voltages above 0.9 for all Heavy Winter forecast scenarios
- The light load scenarios, 60% winter and 60% summer, required additional capacitive support of 5 to 15 MVAR and 45 to 55 MVAR, respectively, to maintain voltage levels between 0.95 to 1.05 pu in the study area.
- The total capacitive compensation, total MVAR, can be configured and distributed between Beaver Creek West and Vail without materially reducing the effectiveness of the total capacitive compensation
 - The total amount of MVAR must meet peak demand
 - The minimum amount of MVAR must be available
- The N-2 230kV condition places Wolcott, Vail, and Beaver Creek West on a ring at the end of a radial line from Robinson Rack to Avon resulting in a weak system in the N-2 condition. After Gilma-Avon is energized, significant voltage swings (>5%) are observed when switching in large increments of capacitive support during peak loading.

Recommendations:


An additional 20 to 25 MVAR of capacitive voltage support distributed proportionately across the previously recommended 115 kV N-2 solutions would likely provide sufficient voltage support for the additional Wolcott load during the Heavy Winter scenarios. Depending on the system conditions during an N-2 event, operational procedures may need to be developed to address the observed line overloads. This additional 25 MVAR compensation for the additional

Wolcott load results in 100 MVAR to restore the study area bus voltages to between 0.95 and 1.05 pu and provides for further economic development beyond the WECC approved assumption of 1% year-over-year for the study area.


Please reference the map, diagrams, and photos of the study area and substations below. Additionally, cumulative and substation specific load totals are available at the end of the document for each forecast scenario.

I. Appendix


Study Area:




115kV N-2 Slider Diagram




230kV Wolcott N-2 Slider Diagram





V7 One-Line




U8 One-Line





Avon:




Beaver Creek West:




Gilman:



Vail:



Wolcott:



Forecasted Load Totals

To determine the appropriate total and incremental step sizes required within the study area multiple load forecasts were used to attempt to decrease forecasting error. Loads within the study area were extrapolated to 2042 from PI data, base case values, and PSCo load forecasts for PSCo owned substations. HCE provided load forecasts were used for Beaver Creek West, Avon, and Vail substations. Base case 2033 (33HW1 and 33HS1) winter and summer peaking values were used for generation and loads at substations outside of the study area and were not forecasted beyond 2033. The substations and their load values are stated in the load specific tables 2 through 5 below.

Table 1

| | Scenario Total Load | | | |
|---|---------------------|----|--------|----------|
| | Ideal Range (MVAR) | | P (MW) | Q (MVAR) |
| 33HS1 - w/o line upgrades | 5 | 15 | 173.49 | 3.27 |
| 33HS1 - w/ line upgrades | 5 | 15 | 173.49 | 3.27 |
| 33HS1 - 2042 PI Data | 15 | 25 | 128.94 | 26.70 |
| 33HS1 - 2042 PI Data w/ HCE Forecast | 15 | 25 | 161.29 | 6.49 |
| 33HS1 - 2042 Load Forecast | 5 | 15 | 189.57 | 7.67 |
| 33HS1 - 60% 2042 PI Data | 0 | 0 | 77.36 | 16.02 |
| 33HS1 - 60% 2042 PI Data w/ HCE Forecast | 0 | 0 | 96.77 | 3.89 |
| 33HS1 - 60% 2042 Load Forecast | 0 | 0 | 113.80 | 3.42 |
| 33HW1 - w/o line upgrades | 55 | 65 | 233.61 | 11.78 |
| 33HW1 - w/ line upgrades | 55 | 65 | 233.61 | 11.78 |
| 33HW1 - 2042 PI Data | 25 | 35 | 256.80 | 7.34 |
| 33HW1 - 2042 PI Data w/ HCE Forecast | 60 | 70 | 324.29 | -12.78 |
| 33HW1 - 2042 Load Forecast from 33HW1 | 65 | 75 | 250.78 | 11.35 |
| 33HW1 - 60% 2042 PI Data | 0 | 10 | 154.32 | 4.46 |
| 33HW1 - 60% 2042 PI Data w/ HCE Forecast | 0 | 0 | 194.57 | -7.67 |
| 33HW1 - 60% 2042 Load Forecast from 33H | 20 | 30 | 150.47 | 6.81 |

Table 2

| | | | | Base Case Loads | | | |
|---------|----------|-----|-------|-----------------|----------|--------|----------|
| | | | | 33HW1 | | 33HS1 | |
| Bus No. | Bus Name | kV | ID | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) |
| 79006 | BEAVERCU | 115 | HC | 43.08 | 4.53 | 22.24 | -6.30 |
| 79092 | AVON | 115 | HC | 22.13 | -1.27 | 11.26 | -1.56 |
| 79066 | VAIL | 115 | HC | 42.18 | -5.91 | 21.42 | -10.26 |
| 70199 | GILMAN | 115 | P1 | 1.44 | 0.21 | 1.47 | 0.42 |
| 70281 | MAYFLOW | 115 | P1 | 6.74 | -2.30 | 6.89 | -4.36 |
| 70281 | MAYFLOW | 115 | P2 | 1.38 | -0.16 | 1.41 | -0.13 |
| 70281 | MAYFLOW | 115 | IN | 21.34 | 3.14 | 12.12 | 3.14 |
| 70114 | CLIMAX | 115 | IN | 29.06 | 13.28 | 29.06 | 13.28 |
| 70257 | LEADVIL1 | 115 | P1 | 1.48 | -0.36 | 1.51 | -0.86 |
| 70258 | LEADVIL2 | 115 | P2 | 3.13 | -0.65 | 3.20 | 3.36 |
| 70418 | SUMMIT1 | 115 | P1 | 9.11 | 1.32 | 9.29 | 1.34 |
| 70155 | DILLON | 115 | P1 | 5.87 | 0.20 | 5.99 | 1.14 |
| 70156 | DILLON | 230 | P3 | 9.79 | 0.90 | 10.00 | 6.94 |
| 70156 | DILLON | 230 | P4 | 0.67 | 0.45 | 0.68 | 0.25 |
| 70064 | BRECKRDC | 230 | P1 | 6.93 | -0.03 | 7.07 | -1.03 |
| 70064 | BRECKRDC | 230 | P2 | 8.23 | 1.81 | 8.40 | 0.36 |
| 70064 | BRECKRDC | 230 | P3 | 8.37 | 0.19 | 8.54 | -0.85 |
| 70057 | PTARMGN | 230 | P1 | 8.56 | -3.49 | 8.73 | -2.27 |
| 70032 | ALMA | 230 | P1 | 4.14 | -0.09 | 4.22 | 0.68 |
| | | | HCE | 107.39 | -2.64 | 54.91 | -18.12 |
| | | | PSCo | 126.22 | 14.43 | 118.58 | 21.39 |
| | | | Total | 233.61 | 11.78 | 173.49 | 3.27 |

Table 3

| | | | | 2042 Load Forecast from PI Data | | | | | | | |
|---------|----------|-----|-------|---------------------------------|----------|------------|----------|--------|----------|------------|----------|
| | | | | Winter | | 60% Winter | | Summer | | 60% Summer | |
| Bus No. | Bus Name | kV | ID | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) |
| 79006 | BEAVERCU | 115 | HC | 19.61 | 2.84 | 11.77 | 1.71 | 11.87 | 2.92 | 7.12 | 1.75 |
| 79092 | AVON | 115 | HC | 22.17 | 1.79 | 13.30 | 1.08 | 12.66 | 1.69 | 7.60 | 1.02 |
| 79066 | VAIL | 115 | HC | 12.87 | 1.51 | 7.72 | 0.90 | 7.46 | 1.63 | 4.48 | 0.98 |
| 70199 | GILMAN | 115 | P1 | 0.61 | -0.05 | 0.37 | -0.03 | 0.35 | -0.07 | 0.21 | -0.04 |
| 70281 | MAYFLOW | 115 | P1 | 14.19 | -3.55 | 8.51 | -2.13 | 1.76 | 1.76 | 1.06 | 1.06 |
| 70281 | MAYFLOW | 115 | P2 | 1.80 | -0.36 | 1.08 | -0.22 | 0.95 | -0.36 | 0.57 | -0.22 |
| 70281 | MAYFLOW | 115 | IN | 11.40 | -2.85 | 6.91 | -1.73 | 1.43 | 1.43 | 0.86 | 0.86 |
| 70114 | CLIMAX | 115 | IN | 28.77 | 13.15 | 17.43 | 7.97 | 28.77 | 13.15 | 17.26 | 7.89 |
| 70257 | LEADVIL1 | 115 | P1 | 3.64 | -0.47 | 2.19 | -0.28 | 2.01 | -0.38 | 1.20 | -0.23 |
| 70258 | LEADVIL2 | 115 | P2 | 7.55 | 2.13 | 4.53 | 1.28 | 4.57 | 2.39 | 2.74 | 1.43 |
| 70418 | SUMMIT1 | 115 | P1 | 20.09 | -2.44 | 12.05 | -1.46 | 10.95 | -2.16 | 6.57 | -1.30 |
| 70155 | DILLON | 115 | P1 | 6.40 | -0.31 | 3.84 | -0.19 | 4.96 | -0.59 | 2.98 | -0.35 |
| 70156 | DILLON | 230 | P3 | 27.74 | 1.98 | 16.64 | 1.19 | 4.80 | -2.63 | 2.88 | -1.58 |
| 70156 | DILLON | 230 | P4 | 1.21 | -0.79 | 0.73 | -0.48 | 1.25 | -0.81 | 0.75 | -0.48 |
| 70064 | BRECKRDC | 230 | P1 | 12.72 | 0.73 | 7.63 | 0.44 | 5.13 | 1.02 | 3.08 | 0.61 |
| 70064 | BRECKRDC | 230 | P2 | 12.41 | -2.03 | 7.45 | -1.22 | 3.39 | -0.32 | 2.03 | -0.19 |
| 70064 | BRECKRDC | 230 | P3 | 26.76 | 0.58 | 16.06 | 0.35 | 13.26 | 2.40 | 7.96 | 1.44 |
| 70057 | PTARMGN | 230 | P1 | 17.55 | -5.05 | 10.53 | -3.03 | 9.00 | 4.87 | 5.40 | 2.92 |
| 70032 | ALMA | 230 | P1 | 9.30 | 0.52 | 5.58 | 0.31 | 4.40 | 0.76 | 2.64 | 0.46 |
| | | | HCE | 54.66 | 6.14 | 32.79 | 3.69 | 31.99 | 6.24 | 19.20 | 3.74 |
| | | | PSCo | 202.15 | 1.19 | 121.53 | 0.78 | 96.95 | 20.46 | 58.17 | 12.28 |
| | | | Total | 256.80 | 7.34 | 154.32 | 4.46 | 128.94 | 26.70 | 77.36 | 16.02 |

Table 4

| 2042 Load Forecast from PI data with HCE Forecast | | | | | | | | | | | |
|---|----------|-----|-------|--------|----------|------------|----------|--------|----------|------------|----------|
| Bus No. | Bus Name | kV | ID | Winter | | 60% Winter | | Summer | | 60% Summer | |
| | | | | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) |
| 79006 | BEAVERCU | 115 | HC | 48.99 | -3.88 | 29.39 | -2.33 | 26.15 | -3.88 | 15.69 | -2.33 |
| 79092 | AVON | 115 | HC | 25.31 | -3.26 | 15.19 | -1.96 | 13.21 | -3.26 | 7.93 | -1.96 |
| 79066 | VAIL | 115 | HC | 47.84 | -6.83 | 28.70 | -4.10 | 24.98 | -6.83 | 14.99 | -4.10 |
| 70199 | GILMAN | 115 | P1 | -0.61 | -0.05 | -0.37 | -0.03 | -0.35 | -0.07 | -0.21 | -0.04 |
| 70281 | MAYFLOW | 115 | P1 | -14.19 | -3.55 | -8.51 | -2.13 | -1.76 | 1.76 | -1.06 | 1.06 |
| 70281 | MAYFLOW | 115 | P2 | -1.80 | -0.36 | -1.08 | -0.22 | -0.95 | -0.36 | -0.57 | -0.22 |
| 70281 | MAYFLOW | 115 | IN | -11.40 | -2.85 | -6.84 | -1.71 | -1.43 | 1.43 | -0.86 | 0.86 |
| 70114 | CLIMAX | 115 | IN | -28.77 | 13.15 | -17.26 | 7.89 | -28.77 | 13.15 | -17.26 | 7.89 |
| 70257 | LEADVIL1 | 115 | P1 | -3.64 | -0.47 | -2.19 | -0.28 | -2.01 | -0.38 | -1.20 | -0.23 |
| 70258 | LEADVIL2 | 115 | P2 | -7.55 | 2.13 | -4.53 | 1.28 | -4.57 | 2.39 | -2.74 | 1.43 |
| 70418 | SUMMIT1 | 115 | P1 | -20.09 | -2.44 | -12.05 | -1.46 | -10.95 | -2.16 | -6.57 | -1.30 |
| 70155 | DILLON | 115 | P1 | -6.40 | -0.31 | -3.84 | -0.19 | -4.96 | -0.59 | -2.98 | -0.35 |
| 70156 | DILLON | 230 | P3 | -27.74 | 1.98 | -16.64 | 1.19 | -4.80 | -2.63 | -2.88 | -1.58 |
| 70156 | DILLON | 230 | P4 | -1.21 | -0.79 | -0.73 | -0.48 | -1.25 | -0.81 | -0.75 | -0.48 |
| 70064 | BRECKRDC | 230 | P1 | -12.72 | 0.73 | -7.63 | 0.44 | -5.13 | 1.02 | -3.08 | 0.61 |
| 70064 | BRECKRDC | 230 | P2 | -12.41 | -2.03 | -7.45 | -1.22 | -3.39 | -0.32 | -2.03 | -0.19 |
| 70064 | BRECKRDC | 230 | P3 | -26.76 | 0.58 | -16.06 | 0.35 | -13.26 | 2.40 | -7.96 | 1.44 |
| 70057 | PTARMGN | 230 | P1 | -17.55 | -5.05 | -10.53 | -3.03 | -9.00 | 4.87 | -5.40 | 2.92 |
| 70032 | ALMA | 230 | P1 | -9.30 | 0.52 | -5.58 | 0.31 | -4.40 | 0.76 | -2.64 | 0.46 |
| | | | HCE | 122.14 | -13.98 | 73.28 | -8.39 | 64.34 | -13.98 | 38.60 | -8.39 |
| | | | PSCo | 202.15 | 1.19 | 121.29 | 0.72 | 96.95 | 20.46 | 58.17 | 12.28 |
| | | | Total | 324.29 | -12.78 | 194.57 | -7.67 | 161.29 | 6.49 | 96.77 | 3.89 |

Table 5

| 2042 Forecast from 33HW1 | | | | | | | | | | | |
|--------------------------|----------|-----|-------|--------|----------|------------|----------|--------|----------|------------|----------|
| Bus No. | Bus Name | kV | ID | Winter | | 60% Winter | | Summer | | 60% Summer | |
| | | | | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) | P (MW) | Q (MVAR) |
| 79006 | BEAVERCU | 115 | HC | 47.11 | 4.95 | 28.27 | 2.97 | 26.15 | -3.88 | 15.69 | -2.33 |
| 79092 | AVON | 115 | HC | 24.20 | -1.38 | 14.52 | -0.83 | 13.21 | -3.26 | 7.93 | -1.96 |
| 79066 | VAIL | 115 | HC | 46.13 | -6.46 | 27.68 | -3.88 | 24.98 | -6.83 | 14.99 | -4.10 |
| 70199 | GILMAN | 115 | P1 | 1.58 | 0.23 | 0.95 | 0.14 | 1.61 | 0.46 | 0.97 | 0.26 |
| 70281 | MAYFLOW | 115 | P1 | 7.37 | -2.52 | 4.42 | -1.51 | 7.53 | -4.78 | 4.51 | -3.04 |
| 70281 | MAYFLOW | 115 | P2 | 1.51 | -0.17 | 0.90 | -0.10 | 1.54 | -0.14 | 0.92 | -0.09 |
| 70281 | MAYFLOW | 115 | IN | 21.34 | 3.14 | 12.80 | 1.88 | 12.00 | 3.11 | 7.20 | 1.86 |
| 70114 | CLIMAX | 115 | IN | 29.06 | 13.28 | 17.43 | 7.97 | 28.77 | 13.15 | 17.26 | 7.89 |
| 70257 | LEADVIL1 | 115 | P1 | 1.61 | -0.39 | 0.97 | -0.23 | 1.65 | -0.94 | 0.99 | -0.57 |
| 70258 | LEADVIL2 | 115 | P2 | 3.43 | -0.71 | 2.06 | -0.42 | 3.50 | 3.67 | 2.10 | 2.16 |
| 70418 | SUMMIT1 | 115 | P1 | 9.96 | 1.44 | 5.98 | 0.87 | 10.16 | 1.46 | 6.09 | 0.71 |
| 70155 | DILLON | 115 | P1 | 6.42 | 0.22 | 3.85 | 0.13 | 6.55 | 1.24 | 3.93 | 0.68 |
| 70156 | DILLON | 230 | P3 | 10.70 | 0.99 | 6.42 | 0.59 | 10.93 | 7.58 | 6.55 | 4.29 |
| 70156 | DILLON | 230 | P4 | 0.73 | 0.49 | 0.44 | 0.30 | 0.75 | 0.27 | 0.45 | 0.16 |
| 70064 | BRECKRDC | 230 | P1 | 7.58 | -0.03 | 4.55 | -0.02 | 7.74 | -1.13 | 4.64 | -0.76 |
| 70064 | BRECKRDC | 230 | P2 | 9.00 | 1.97 | 5.40 | 1.18 | 9.19 | 0.39 | 5.51 | 0.14 |
| 70064 | BRECKRDC | 230 | P3 | 9.15 | 0.21 | 5.49 | 0.12 | 9.15 | -0.94 | 5.60 | -0.70 |
| 70057 | PTARMGN | 230 | P1 | 9.36 | -3.81 | 5.62 | -2.29 | 9.55 | -2.49 | 5.73 | -1.62 |
| 70032 | ALMA | 230 | P1 | 4.53 | -0.10 | 2.72 | -0.06 | 4.62 | 0.74 | 2.77 | 0.43 |
| | | | HCE | 117.45 | -2.89 | 70.47 | -1.74 | 64.34 | -13.98 | 38.60 | -8.39 |
| | | | PSCo | 133.33 | 14.24 | 80.00 | 8.54 | 125.23 | 21.65 | 75.20 | 11.81 |
| | | | Total | 250.78 | 11.35 | 150.47 | 6.81 | 189.57 | 7.67 | 113.80 | 3.42 |